Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ABS613

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LANZENDORF, TIM			Phone #
Mailing Address: 11848 CO J			
City: LODI	State: WI	Zip Code: 53553	
County: Price	Co. Permit #:	Notification #: 9280116002	Completed: 10-03-2023

1. Well Location

Town of LAKE

Fire # (if avail.)

Street Address or Road Name and Number: KAISER

Subdivision Name | Lot # | Block #

Well Constructor (Business Name): HOLT, JOHN A	Lic. #: 250	Facility ID # (Public Wells)	Latitude / Longitude in Decimal Degree (DD): 45.88394 °N -90.54144 °W
		Well Plan Approval #	Method Code: SCR006
Address: JOHN HOLT WELL DRILLING N15485 TOWN HALL RD PARK FALLS WI 54552-9310		Approval Date (mm-dd-yyyy)	SW SE / or Govt Lot #; Section: 6; Township: 39 N; Range: 1 W
Hicap Permanent Well #	Common Well #:	Specific Capacity: 1.3	

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

3. Well serves 1 # of CAMPER/HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	26

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	Y-SAND & GRAVEL	Surface	26

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53B PE	Surface	26
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

8 ft. below ground surface

10. Pump Test

Pumping level 16 ft. below surface

Pumping at 10 GP M for 8 Hrs.

Pumping Method ? Other

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JH	250	02-29-2024
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		25

Comment: JEFFREY HOLT SIGNED AS RIG OPERATOR

3/4/24 DNR ENTERED COORDINATES AND SECTION. NOT PROVIDED BY DRILLER

Created On: 03-04-2024 Updated On: 03-26-2024 Review Status: APPROVED