

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ABS879		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707 Form 3300-077A									
Property Owner ANDY SCHOMER					Phone #										
Mailing Address 2208 21 STREET					Town of RICE LAKE 2208										
City RICE LAKE					State WI		Zip Code 54868								
County Barron		Co. Permit #		Notification # 9144787901		Completed 07-29-2023		Subdivision Name		Lot #		Block #			
Well Constructor (Business Name) RUTHERFORD WELL DRLG INC				Lic. # 6764		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.5241 °N -91.7237 °W				Method Code GPS008	
Address 2422 27 1/2 AVE RICE LAKE WI 54868				Well Plan Approval #				SW SW		Section 10		Township 35 N		Range 11 W	
				Approval Date (mm-dd-yyyy)				or Govt Lot #							
Hicap Permanent Well #			Common Well #			Specific Capacity 0			2. Well Type Replacement of previous unique well # constructed in						
									Reason for replaced or reconstructed well ? LOW YIELD						
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No				Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
4		Surface		68		No Rotary - Mud Circulation				No					
						No Rotary - Air				No					
						No Rotary - Air & Foam				No					
						No Drill-Through Casing Hammer									
						No Reverse Rotary									
						Yes Cable-tool Bit 4in. dia...				No					
						No Dual Rotary				No					
						No Temp. Outer Casing ___ in. dia									
						No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
T		Q		S				T-TAN/BROWN Q-CAVING S-SAND		Surface		28			
G		V		C				G-GRAY V-NON-CAVING C-CLAY		28		34			
T		M		S				T-TAN/BROWN M-MEDIUM S-SAND		34		68			
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
4		WHEATLAND STEEL ASTM53 10.79LB PER FT				Surface		64							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
4		STAINLESS 12SLOT				64		68							
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
GRANULAR BENTONITE				Surface		28		2 S							
9. Static Water Level															
28 ft. below ground surface															
10. Pump Test															
Pumping level 40 ft. below surface															
Pumping at 17 GP M for 2 Hrs.															
Pumping Method ? Test Pump															
11. Well Is															
14 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? Yes															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller															
Lic #				Date Signed											
TR				4719				03-16-2024							
Drill Rig Operator				Lic or Reg #				Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	78	POWTS dispersal component (soil absorption unit or mound)	=	65

Comment:

Created On: 03-16-2024

Updated On: 05-15-2024

Review Status: APPROVED