Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ABT735

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: YAHNKE, SHARRON	Phone #
Mailing Address: 11341 COUNTY ROAD S	
City: MILLADORE	State: WI / Zip Code: 54454
County: Wood	Co. Permit #: W-24-036 / Notification #: 9474533901 / Completed: 04-30-2024
Well Constructor (Business Name): ALL AMERICAN WELL & PUMP	Lic. #: 7197 / Facility ID # (Public Wells)
Address: 10564 RANGE LINE RD, AUBURNDALE WI 54412	Well Plan Approval # / Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well # / Specific Capacity: 0

1. Well Location

Town of MILLADORE	Fire # (if avail.): 11341
Street Address or Road Name and Number: 11341 COUNTY ROAD S	
Subdivision Name	Lot # / Block #
Latitude / Longitude in Decimal Degree (DD): 44.6579 °N -89.8658 °W	Method Code: GPS008
SE SE or Govt Lot #	Section: 11 / Township: 25 N / Range: 5 E

2. Well Type Replacement
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
NOT USED
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	40
6	40	240

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		C-CLAY	Surface	11
	D	Q		D-DECOMPOSED/WEATHERED Q-GRANITE	11	16
		Q		Q-GRANITE	16	240

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL, 18.97, A53, IPSCO, P.E WELDED	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	40	5 S

9. Static Water Level
7 ft. below ground surface

10. Pump Test
Pumping level 240 ft. below surface
Pumping at 3 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
FJ	6490	04-30-2024
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		114

Comment: WELL WAS DRY WHEN DRILLED AND HAD TO BE HYDRO FRACKED.

Created On: 04-26-2024 Updated On: 05-31-2024 Review Status: APPROVED