

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ABT735		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner YAHNKE, SHARRON						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address 11341 COUNTY ROAD S								Town of MILLADORE				11341									
City MILLADORE						State WI		Zip Code 54454				Street Address or Road Name and Number 11341 COUNTY ROAD S									
County Wood		Co. Permit # W-24-036		Notification # 9474533901		Completed 04-30-2024		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) ALL AMERICAN WELL & PUMP				Lic. # 7197		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.6579 °N -89.8658 °W				Method Code GPS008							
Address 10564 RANGE LINE RD AUBURNDALE WI 54412				Well Plan Approval #		SE SE		Section 11		Township 25 N		Range 5 E									
				Approval Date (mm-dd-yyyy)		or Govt Lot #															
Hicap Permanent Well #		Common Well #		Specific Capacity 0		2. Well Type Replacement				of previous unique well # constructed in											
Reason for replaced or reconstructed well ? NOT USED																					
3. Well serves 1 # of HOME				Hicap Well ? No		Construction Type Drilled															
Private, potable				Hicap Property ? No																	
Heat Exchange ___ # of drillholes				Hicap Potable ? No																	
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8		Surface		40		<u>No</u> Rotary - Mud Circulation				<u>No</u>		C		C-CLAY		Surface		11			
6		40		240		<u>Yes</u> Rotary - Air				<u>Yes</u>		D Q		D-DECOMPOSED/WEATHERED Q-GRANITE		11		16			
						<u>No</u> Rotary - Air & Foam				<u>No</u>		Q		Q-GRANITE		16		240			
						<u>No</u> Drill-Through Casing Hammer															
						<u>No</u> Reverse Rotary															
						<u>No</u> Cable-tool Bit ___ in. dia...				<u>No</u>											
						<u>No</u> Dual Rotary				<u>No</u>											
						<u>No</u> Temp. Outer Casing ___ in. dia															
						<u>No</u> Removed? ___ depth ft. (If NO explain on back side)															
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		7 ft. below ground surface				24 in. above grade							
6		STEEL, 18.97, A53, IPSCO, P.E WELDED				Surface		40		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 240 ft. below surface				Disinfected ? Yes							
										Pumping at 3 GP M for 1 Hrs.				Capped ? Yes							
										Pumping Method ? Airlift											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? Yes							
Method		TREMIE PIPE - PUMPED																			
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? Yes													
NEAT CEMENT GROUT		Surface		40		5 S															
13. Constructor / Supervisory Driller														Lic #		Date Signed					
FJ														6490		04-30-2024					
Drill Rig Operator														Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		114

Comment: WELL WAS DRY WHEN DRILLED AND HAD TO BE HYDRO FRACKED.

Created On: 04-26-2024

Updated On: 05-31-2024

Review Status: APPROVED