Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ABU077

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KUPIETZ, TONY	Phone #
Mailing Address: 2591 8 1/2 AVE	
City: CHETEK	State: WI — Zip Code: 54728
County: Barron	Co. Permit #: — Notification #: 9191180901 — Completed: 10-20-2023
Well Constructor (Business Name): RUTHERFORD WELL DRLG INC	Lic. #: 6764 — Facility ID # (Public Wells):
Address: 2422 27 1/2 AVE, RICE LAKE WI 54868	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.5

1. Well Location

Town of CHETEK	Fire # (if avail.): 2591			
Street Address or Road Name and Number: 8 1/4 AVE				
Subdivision Name	Lot #	Block #		
Latitude / Longitude in Decimal Degree (DD): 45.3246 °N -91.6255 °W	Method Code: GPS008			
SE SE or Govt Lot #	Section: 20	Township: 33 N	Range: 10 W	

2. Well Type New Well
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	40

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 3.75in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K	M	I	I	K-BLACK M-MEDIUM I-SOIL-ORGANIC I-W/SOIL-ORGANIC	Surface	1
T	Q	S	S	T-TAN/BROWN Q-CAVING S-SAND S-SANDY	1	28
G	V	C	C	G-GRAY V-NON-CAVING C-CLAY C-CLAYEY	28	32
T	N	S	S	T-TAN/BROWN N-FINE S-SAND S-SANDY	32	40

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	WHEATLAND ASTM A53 10.79LB PER FOOT	Surface	36
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3	STAINLESS 12 SLOT	36	40

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	10	1 S

9. Static Water Level
9 ft. below ground surface

10. Pump Test
Pumping level 20 ft. below surface
Pumping at 6 GP M for 4 Hrs.
Pumping Method ? Test Pump

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TR	4719	05-08-2024
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	=	60	POWTS dispersal component (soil absorption unit or mound)	=	70

Comment:

Created On: 05-08-2024 Updated On: 05-31-2024 Review Status: APPROVED