

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ABU083		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner JOHNSON, CYNTHIA						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 5464 BROOKWOOD LANE								Town of SIGEL				5486	
City VESPER						State WI		Zip Code 54489				Street Address or Road Name and Number	
5486 BROOKWOOD LANE								Subdivision Name				Lot #	
County Wood						Co. Permit # 24024		Notification # 9496057601				Completed 05-15-2024	
Well Constructor (Business Name) ALL AMERICAN WELL & PUMP						Lic. # 7197		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)	
Address 10564 RANGE LINE RD AUBURNDALE WI 54412						Well Plan Approval #		44.4453 °N -89.9538 °W				Method Code GPS008	
Hicap Permanent Well #						Common Well #		Specific Capacity 0				NW SE Section Township Range or Govt Lot # 30 23 N 5 E	
3. Well serves 1 # of HOME						Hicap Well ? No		2. Well Type Replacement				of previous unique well # constructed in	
Private, potable						Hicap Property ? No		Reason for replaced or reconstructed well ?				DUG WELL	
Heat Exchange ___ # of drillholes						Hicap Potable ? No		Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock										
8 Surface 40			No Rotary - Mud Circulation No										
6 40 200			Yes Rotary - Air Yes										
			No Rotary - Air & Foam No										
			No Drill-Through Casing Hammer										
			No Reverse Rotary										
			No Cable-tool Bit ___ in. dia... No										
			No Dual Rotary No										
			Yes Temp. Outer Casing 8in. dia										
			Yes Removed? 4depth ft. (If NO explain on back side)										
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.) To (ft.)				
S			S-SAND						Surface 4				
N			N-SANDSTONE						4 23				
Q			Q-GRANITE						23 200				
6. Casing, Liner, Screen													
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly						From (ft.) To (ft.)				
6			STEEL, 18.97, A53, IPSCO, P.E WELDED						Surface 40				
Dia. (in.)			Screen type, material & slot size						From (ft.) To (ft.)				
7. Grout or Other Sealing Material													
Method TREMIE PIPE - PUMPED													
Kind of Sealing Material			From (ft.)			To (ft.)			# Sacks Cement				
NEAT CEMENT GROUT			Surface			40			10 S				
9. Static Water Level													
12 ft. below ground surface													
10. Pump Test													
Pumping level 200 ft. below surface													
Pumping at 2 GP M for 1 Hrs.													
Pumping Method ? Airlift													
11. Well Is													
24 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ? Yes													
Filled & Sealed Well(s) as needed? Yes													
13. Constructor / Supervisory Driller													
Lic #			Date Signed										
FJ			6490 05-15-2024										
Drill Rig Operator			Lic or Reg # Date Signed										

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		83

Comment: WELL WAS DRY WHEN DRILLED. HAD TO BE HYDRO FRACKED

Created On: 05-08-2024 Updated On: 10-31-2024 Review Status: APPROVED