

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ABU120		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707 Form 3300-077A				
Property Owner FREINDSHUS					Phone #					
Mailing Address POBOX 161					1. Well Location					
City STONE LAKE					State WI		Zip Code 54876		Fire # (if avail.)	
County Sawyer					Co. Permit #		Notification # 9205226701		Completed 04-16-2024	
Well Constructor (Business Name) RUTHERFORD WELL DRLG INC					Lic. # 6764		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)	
Address 2422 27 1/2 AVE RICE LAKE WI 54868					Well Plan Approval #		Approval Date (mm-dd-yyyy)		45.8808 °N -91.4889 °W	
									Method Code GPS008	
Hicap Permanent Well #					Common Well #		Specific Capacity 0		SW NE Section Township Range or Govt Lot # 9 39 N 9 W	
3. Well serves 1 # of HOME					Hicap Well ? No		Hicap Property ? No		2. Well Type New Well	
Private, potable					Hicap Potable ? No		Construction Type Drilled		of previous unique well # constructed in Reason for replaced or reconstructed well ?	
Heat Exchange ___ # of drillholes										
4. Potential Contamination Sources - ON REVERSE SIDE										
5. Drillhole Dimensions and Construction Method										
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole				Lower Open Bedrock		8. Geology	
4	Surface	64	No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary Yes Cable-tool Bit 3.75in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)						Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.) K M I I K-BLACK M-MEDIUM I-SOIL-ORGANIC I-W/SOIL-ORGANIC Surface 2 T Q S T-TAN/BROWN Q-CAVING S-SAND 2 12 G V C Z G-GRAY V-NON-CAVING C-CLAY Z-W/COBBLES/BOULDERS 12 26 G V C S G-GRAY V-NON-CAVING C-CLAY S-SANDY 26 50 T N S T-TAN/BROWN N-FINE S-SAND 50 64	
6. Casing, Liner, Screen										
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)	To (ft.)	9. Static Water Level			
4	WHEATLAND ASTM A53 10.79 LBS PER FOOT				Surface	60	20 ft. below ground surface			
Dia. (in.)	Screen type, material & slot size				From (ft.)	To (ft.)	10. Pump Test			
3	STAINLESS STEAL 12 SLOT				60	64	Pumping level 50 ft. below surface Pumping at 18 GP M for 12 Hrs. Pumping Method ? Test Pump			
7. Grout or Other Sealing Material										
Method MOUNDED										
Kind of Sealing Material				From (ft.)	To (ft.)	# Sacks Cement		11. Well Is		
GRANULAR BENTONITE				Surface	20	2 S		Developed ? Yes Disinfected ? Yes Capped ? Yes		
12. Notified Owner of need to fill & seal ? No										
Filled & Sealed Well(s) as needed? No										
13. Constructor / Supervisory Driller								Lic #		Date Signed
TR								4719		05-08-2024
Drill Rig Operator								Lic or Reg #		Date Signed

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	=	48	POWTS dispersal component (soil absorption unit or mound)	=	75

Comment:

Created On: 05-08-2024

Updated On: 06-03-2024

Review Status: APPROVED