

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ABU207		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner BECKER, RICHARD						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 9350 COUNTY ROAD F								Town of SHERRY				8860							
City MILLADORE						State WI		Zip Code 54454				Street Address or Road Name and Number 8860 VRUWINK ROAD							
County Wood		Co. Permit # 24045		Notification # 9502983901		Completed 05-22-2024		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) ALL AMERICAN WELL & PUMP				Lic. # 7197		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.5687 °N -89.9043 °W				Method Code GPS008					
Address 10564 RANGE LINE RD AUBURNDAL WI 54412				Well Plan Approval #		NW NW Section Township Range or Govt Lot # 15 24 N 5 E		2. Well Type New Well				of previous unique well # constructed in							
Hicap Permanent Well #				Common Well #		Specific Capacity 0				Reason for replaced or reconstructed well ?									
3. Well serves 1 # of HOME						Hicap Well ? No		Construction Type Drilled				Private, potable							
Heat Exchange ____ # of drillholes						Hicap Property ? No													
Hicap Potable ? No																			
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock						Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)						
8 Surface 53			<u>No</u> Rotary - Mud Circulation <u>No</u>						C		C-CLAY		Surface 13						
6 53 240			<u>Yes</u> Rotary - Air <u>Yes</u>						H		H-SHALE		13 140						
			<u>No</u> Rotary - Air & Foam <u>No</u>						Q		Q-GRANITE		140 240						
			<u>No</u> Drill-Through Casing Hammer																
			<u>No</u> Reverse Rotary																
			<u>No</u> Cable-tool Bit ____ in. dia... <u>No</u>																
			<u>No</u> Dual Rotary <u>No</u>																
			<u>Yes</u> Temp. Outer Casing 8in. dia																
			<u>Yes</u> Removed? 13depth ft. (If NO explain on back side)																
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly						From (ft.) To (ft.)		5 ft. below ground surface				24 in. above grade				
6			STEEL, 18.97, A53, IPSCO, P.E WELDED						Surface 53		10. Pump Test				Developed ? Yes				
Dia. (in.)			Screen type, material & slot size						From (ft.) To (ft.)		Pumping level 240 ft. below surface				Disinfected ? Yes				
											Pumping at 1.5 GP M for 1 Hrs.				Capped ? Yes				
											Pumping Method ? Airlift								
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?				No			
Method TREMIE PIPE - PUMPED																			
Kind of Sealing Material			From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?				No						
NEAT CEMENT GROUT			Surface		53		10 S												
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												FJ				6490		05-22-2024	
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		58

Comment:

Created On: 05-13-2024

Updated On: 11-01-2024

Review Status: APPROVED