Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ABV535

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MELICHAR, ALAN	Phone #
Mailing Address: 810 CHURCH ST UNIT 2	
City: ALLENTON	State: WI — Zip Code: 53002
County: Rusk	Co. Permit #: — Notification #: 9539255001 — Completed: 06-18-2024
Well Constructor (Business Name): ATWOOD, THOMAS	Lic. #: 15 — Facility ID # (Public Wells):
Address: ATWOOD WELL DRILLING W11501 TRAILS END RD BRUCE WI 54819-9722	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.6

1. Well Location

Town of STUBBS	Fire # (if avail.): W12817
Street Address or Road Name and Number: W12817 TYMAN RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.4607 °N -91.334 °W	Method Code: SCR002
NW NW or Govt Lot #	Section: 2 — Township: 34 N — Range: 8 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	40

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	Z	C	T-TAN/BROWN Q-CAVING Z-CLAY & GRAVEL C-CLAYEY	Surface	38
T	W	G		T-TAN/BROWN W-WATER BEARING G-GRAVEL/STONES	38	40

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTMA53, 19LBS FT, WELDED NTP	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		2 S

9. Static Water Level

25 ft. below ground surface

10. Pump Test

Pumping level 34 ft. below surface

Pumping at 5 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TAA	15	06-25-2024
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	=	50

Comment:

Created On: 06-25-2024 Updated On: 07-15-2024 Review Status: APPROVED