Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ABV566

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BELANGER RICHARD	Phone #
Mailing Address: E BUCKHORN RD	
City: PARK FALLS	State: WI — Zip Code: 54552
County: Price	Co. Permit #:
Notification #: 9483721401	Completed: 05-24-2024
Well Constructor (Business Name): JOHN HOLT	Lic. #: 250
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: 1264 N 2ND AVE PARK FALLS WI 54552	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.2	

1. Well Location

Town of LAKE

Fire # (if avail.):

Street Address or Road Name and Number: E BUCKHORN RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
45.89719 °N -90.57712 °W	GPS008

SE or Govt Lot #	SE	Section: 35	Township: 40 N	Range: 2 W

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves # of GARDEN

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	73

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
G	G-GRAVEL/STONES	Surface	30
P	P-HARDPAN	30	70
Y	Y-SAND & GRAVEL	70	73

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53B PE	Surface	73
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

9. Static Water Level

18 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 10 GP M for 8 Hrs.

Pumping Method ? Test Pump

11. Well Is

22 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JH	250	06-07-2024
Drill Rig Operator	Lic or Reg #	Date Signed
JH		06-07-2024

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Animal Barn or Barn Pen		50	Privy		50

Comment:

Created On: 06-26-2024 Updated On: 06-26-2024 Review Status: APPROVED