

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ABV717		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner KOBYSKI RICHARD & JOAN						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address W 3288 STATE ROAD 82 E						Town of MARION													
City MAUSTON						State WI		Zip Code 53948				Street Address or Road Name and Number NORTH OF HWY 82 ----- EAST OF COUNTY HWY HH							
County Juneau		Co. Permit #		Notification #		Completed 06-03-2024		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) ROBERTS IRRIGATION CO INC				Lic. # 3262		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.7976 °N -89.9301 °W									
Address 1500 POST RD PLOVER WI 54467				Well Plan Approval # 29-01-013998		SE NW		Section 8		Township 15 N		Method Code GPS008							
				Approval Date (mm-dd-yyyy) 06-20-2016		or Govt Lot #		Range 5 E											
Hicap Permanent Well # 91370				Common Well #		Specific Capacity 0				2. Well Type Reconstruction of previous unique well # ABR215 constructed in 2023									
Reason for replaced or reconstructed well ? CASING SUNK / NOT SEATED																			
3. Well serves 1 # of CENTER PIVOT Private, non-potable Irrigation				Hicap Well ? Yes															
Heat Exchange ___ # of drillholes				Hicap Property ? Yes															
				Hicap Potable ? No						Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock						Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)						
16 Surface 250			No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No Yes Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)						T S N		I I I-SOIL-ORGANIC I-W/SOIL-ORGANIC T-TAN/BROWN S-SAND T-TAN/BROWN S-SOFT/LOOSE N-W/SANDSTONE T-TAN/BROWN N-W/SANDSTONE		Surface 2 2 95 95 118 118 250						
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.) Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.) To (ft.)								11 ft. below ground surface				14 in. above grade				
16 ASTM A53B .375 STEEL WELDED #62.5 PRFT			Surface 118								10. Pump Test				Developed ? Yes				
Dia. (in.) Screen type, material & slot size			From (ft.) To (ft.)								Pumping level 33 ft. below surface				Disinfected ? Yes				
											Pumping at 225 GP M for 2 Hrs.				Capped ? Yes				
											Pumping Method ? Airlift								
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?				No			
Method MOUNDED																			
Kind of Sealing Material		From (ft.) To (ft.) # Sacks Cement								Filled & Sealed Well(s) as needed?				No					
GRANULAR BENTONITE		Surface 118 3 S																	
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												RIC						07-02-2024	
												Drill Rig Operator				Lic or Reg #		Date Signed	
												IA				9217		07-02-2024	

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

WELL CASING SANK OVER TIME. IT WAS SEATED IN A SOFT SANDSTONE. WE ADVANCED 23' OF CASING TO FIRM SANDSTONE AND CLEANED THE BOTTOM OF THE BORE HOLE.

Created On: 07-02-2024

Updated On: 07-22-2024

Review Status: APPROVED