Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: ACA621

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MARY BRETZMAN	Phone #
Mailing Address: 74800 LAKESHORE DRIVE	
City: WASHBURN	State: WI — Zip Code: 54891
County: Bayfield	Co. Permit #: — Notification #: 9676151801 — Completed: 12-23-2024
Well Constructor (Business Name): KOSTAC, CHRISTOPHER L	Lic. #: 7166 — Facility ID # (Public Wells):
Address: KOSTAC WELL DRILLING AND REPAIR, 60358 JOHN JOHNSON RD, ASHLAND WI 54891	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.2

1. Well Location

Town of BARKSDALE	Fire # (if avail.): 74800
Street Address or Road Name and Number: LAKESHORE DRIVE	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 46.65677 °N -90.91618 °W	Method Code: GPS008
NW NE or Govt Lot #:	Section: 7 — Township: 48 N — Range: 4 W

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: FLOWING WELL IN BASEMENT - BETTER TO FILL/SEAL AND DRILL NEW WELL OUTSIDE

Construction Type: Drilled

3. Well serves 1 # of HOME/CABIN

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	62

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 6in. dia...	No
No	Dual Rotary	Yes
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R		C		R-RED C-CLAY	Surface	25
	N	S		N-FINE S-SAND	25	30
		N		N-SANDSTONE	30	62

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL ASTM 53 PLAIN END	Surface	62
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	32	

9. Static Water Level

3 ft. above ground surface

10. Pump Test

Pumping level 20 ft. below surface

Pumping at 20 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
CLK	7166	01-13-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		40

Comment:

Created On: 12-02-2024 Updated On: 10-15-2026 Review Status: APPROVED