

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACA622		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner JOHN LANGHAMMER						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 74850 LAKESHORE DRIVE								Town of BARKSDALE				74850							
City WASHBURN						State WI		Zip Code 54891				Street Address or Road Name and Number LAKESHORE DR							
County Bayfield		Co. Permit #		Notification # 9716159301		Completed 12-02-2024		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) KOSTAC, CHRISTOPHER L				Lic. # 7166		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 46.65732 °N -90.9161 °W				Method Code GPS008					
Address KOSTAC WELL DRILLING AND REPAIR 60358 JOHN JOHNSON RD ASHLAND WI 54806				Well Plan Approval #		NW NE Section Township Range or Govt Lot # 7 48 N 4 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled											
				Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #		Common Well #		Specific Capacity 0															
3. Well serves 1 # of HOME/CABIN Private,potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		52		No Rotary - Mud Circulation		No		R C		R-RED C-CLAY		Surface		25			
						No Rotary - Air		No		N S		N-FINE S-SAND		25		30			
						No Rotary - Air & Foam		No		N		N-SANDSTONE		30		52			
						No Drill-Through Casing Hammer Reverse Rotary													
						Yes Cable-tool Bit 6in. dia...		No											
						No Dual Rotary		Yes											
						No Temp. Outer Casing ___ in. dia													
						No Removed? ___ depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		3 ft. above ground surface				24 in. above grade					
6		STEEL ASTM 53 PLAIN END				Surface		32		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 20 ft. below surface				Disinfected ? Yes					
										Pumping at 20 GP M for 2 Hrs.				Capped ? Yes					
										Pumping Method ? Test Pump									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? No							
Method MOUNDED																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement											
GRANULAR BENTONITE				Surface						Filled & Sealed Well(s) as needed? No									
												13. Constructor / Supervisory Driller				Lic #		Date Signed	
												CLK				7166		01-13-2025	
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		35

Comment: WELL FLOWS AT 2-3 GPM

Created On: 12-02-2024 Updated On: 01-21-2025 Review Status: APPROVED