

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACA634		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner TOM NEAVE					Phone #			1. Well Location				Fire # (if avail.)		
Mailing Address 10202 278TH AVENUE								Village of SALEM LAKES						
City TREVOR					State WI		Zip Code 53179		Street Address or Road Name and Number				10202 278TH AVENUE	
County Kenosha		Co. Permit #		Notification # 9674703001		Completed 11-15-2024		Subdivision Name			Lot # 2		Block # 6	
Well Constructor (Business Name) BOYCE, KENNETH D				Lic. # 6123		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 42.52755 °N -88.14744 °W			Method Code SCR002			
Address BEACH PUMP & WELL SERV INC 10453 W BOYCE LN BEACH PARK IL 60087				Well Plan Approval #		SW SW		Section 21		Township 1 N		Range 20 E		
				Approval Date (mm-dd-yyyy)		or Govt Lot #								
Hicap Permanent Well #			Common Well #			Specific Capacity			2. Well Type New Well					
									of previous unique well # constructed in					
									Reason for replaced or reconstructed well ?					
3. Well serves 1 # of HOME					Hicap Well ? No			Construction Type Drilled						
Private, potable					Hicap Property ? No									
Heat Exchange ___ # of drillholes					Hicap Potable ? No									
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock					
10		Surface		9		No Rotary - Mud Circulation			No					
5		9		68		No Rotary - Air			No					
						No Rotary - Air & Foam			No					
						No Drill-Through Casing Hammer								
						No Reverse Rotary								
						Yes Cable-tool Bit 5in. dia...			No					
						No Dual Rotary			No					
						No Temp. Outer Casing ___ in. dia								
						No Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)			To (ft.)					
K F			K-BLACK F-FILL			Surface			2					
Y C			Y-YELLOW C-CLAY			2			17					
G C			G-GRAY C-CLAY			17			57					
			S-SAND			57			68					
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.)		To (ft.)		11. Well Is					
5		ASTM A-53 BT/C WHEATLAND - COUPLING ASSEMBLY			Surface		68		15 in. above grade					
Dia. (in.)		Screen type, material & slot size			From (ft.)		To (ft.)		Developed ? Yes					
5		5" TELE STAINLESS SLOT # 12, SAND			66		68		Disinfected ? Yes					
									Capped ? Yes					
7. Grout or Other Sealing Material														
Method GROUT DISPLACEMENT (PLUG)														
Kind of Sealing Material			From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? No					
GRANULAR BENTONITE			Surface		9		3 S		Filled & Sealed Well(s) as needed? No					
13. Constructor / Supervisory Driller														
KB			Lic # 6123		Date Signed 12-02-2024									
Drill Rig Operator			Lic or Reg #		Date Signed									
KB			6123		12-02-2024									

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 12-02-2024

Updated On: 07-15-2025

Review Status: APPROVED