

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACA717		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner BART INNIS					Phone #			1. Well Location Fire # (if avail.) 11296			
Mailing Address 11296 WEST US HIGHWAY 2					Town of GURNEY						
City SAXON				State WI		Zip Code 54559		Street Address or Road Name and Number WEST US HIGHWAY 2			
County Iron		Co. Permit #		Notification # 9670387001		Completed 12-04-2024		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) WEBSTER WELL DRILLING INC				Lic. # 665		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 46.51124 °N -90.50727 °W		Method Code SCR006	
Address PO BOX 151 MINOCQUA WI 54548-0151				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 33 47 N 1 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled			
				Approval Date (mm-dd-yyyy)							
Hicap Permanent Well #		Common Well #		Specific Capacity 0							
3. Well serves 1 # of RESTAURANT/TAVERN Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...	
6		Surface		360		No Rotary - Mud Circulation No Rotary - Air No Rotary - Air & Foam No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No Dual Rotary No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				Q S Q-CAVING S-SAND Surface 200 X X-SAND & CLAY 200 300 S G S-SAND G-W/GRAVEL/STONES 300 360	
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is 12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes	
6		18.97 LBS. ASTM A53-B WHEATLAND WELDED JOINTS				Surface		360			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
7. Grout or Other Sealing Material Method MOUNDED											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? No Filled & Sealed Well(s) as needed? Yes	
GRANULAR BENTONITE				Surface		60		4 S			
13. Constructor / Supervisory Driller Lic # Date Signed MND 4634 12-05-2024 Drill Rig Operator Lic or Reg # Date Signed TAS 4688 12-05-2024											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	=	120	Building Drain - Sanitary	=	100
			Septic or Holding, or POWTS Tank	=	110

Comment:

THE CASING OF THE WELL BROKE OFF AT 320 FEET; THIS WELL WAS A DRY HOLE AND IMMEDIATELY ABANDONED. ABANDONMENT REPORT TO FOLLOW. NO WATER SAMPLE WILL BE TAKEN.

Abandonment Type	Abandonment Date	Procedure	Reason
	12/05/2024	ABANDONMENT	CASING BROKE OFF AT 320;'

Created On: 12-05-2024**Updated On:** 12-27-2024**Review Status:** APPROVED