Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACA757

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BURCH			Phone #
Mailing Address: 8345 CTY RD V			
City: CALEDONIA	State: WI	Zip Code: 53108	
County: Juneau	Co. Permit #	Notification #: 9711892501	Completed: 11-20-2024

Well Constructor (Business Name): MARESCH, JACOB J	Lic. #: 7588	Facility ID # (Public Wells)	
Address: W5250 WILEY LANE NEW LISBON WI 53950		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.2	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location
Town of NECEDAH

Fire # (if avail.): W5237

Street Address or Road Name and Number: 26TH STREET

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
43.98778 °N -90.03119 °W	SCR002

NW	SW	Section	Township	Range
or Govt Lot #		33	18 N	4 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Driven Point

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
1.25	Surface	31

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R	E	S	S	R-RED E-CLEAN S-SAND S-SANDY	Surface	31

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
1.25	GALVINIZED STEEL THREADED COUPLINGS ASTM A53	Surface	28
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	JOHNSON STAINLESS STEEL 10 SLOT	28	31

9. Static Water Level
10 ft. below ground surface

10. Pump Test
Pumping level 11 ft. below surface
Pumping at 10 GP H for 1 Hrs.
Pumping Method ? Other

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JM	7588	12-07-2024
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		35
POWTS dispersal component (soil absorption unit or mound)		60

Type	Qualifier	Distance
Building Drain - Sanitary		10
Sewer - Building Sanitary		10

Comment:

Created On: 12-07-2024 Updated On: 10-15-2026 Review Status: APPROVED