Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACA787

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: SCHILLINGER INVESTMENTS		Phone #	
Mailing Address: 10536 HIGHWAY 70 EAST			
City: ARBOR VITAE	State: WI	Zip Code: 54564	
County: Vilas	Co. Permit #:	Notification #: 9646582602	Completed: 12-02-2024

1. Well Location
Town of ARBOR VITAE
Fire # (if avail.): 1170
Street Address or Road Name and Number: OLD HIGHWAY 51 SOUTH
Subdivision Name:
Lot #:
Block #:

Well Constructor (Business Name): WEBSTER WELL DRILLING INC	Lic. #: 665	Facility ID # (Public Wells):	Latitude / Longitude in Decimal Degree (DD): 45.90669 °N -89.68015 °W
		Well Plan Approval #:	Method Code: SCR006
Address: PO BOX 151 MINOCQUA WI 54548-0151		Approval Date (mm-dd-yyyy):	SW NE or Govt Lot #: Section: 36 Township: 40 N Range: 6 E

2. Well Type New Well
of previous unique well #
constructed in
Reason for replaced or reconstructed well ?

Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.5

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	43

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	Q	Y	C	Q-CAVING Y-SAND & GRAVEL C-CLAYEY	Surface	32
	M	S		M-MEDIUM S-SAND	32	43

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18.97 LBS. ASTM A53-B WHEATLAND WELDED JOINTS	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	3' #10 SLOT STAINLESS STEEL SCREEN	40	43

9. Static Water Level
20 ft. below ground surface

10. Pump Test
Pumping level 30 ft. below surface
Pumping at 15 GP M for 1 Hrs.
Pumping Method ? Test Pump

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	18	1 S

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
MND	4634	12-09-2024
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 12-09-2024 Updated On: 12-30-2024 Review Status: APPROVED