

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACA787		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner SCHILLINGER INVESTMENTS						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 10536 HIGHWAY 70 EAST						Town of ARBOR VITAE						1170			
City ARBOR VITAE						State WI		Zip Code 54564				Street Address or Road Name and Number OLD HIGHWAY 51 SOUTH			
County Vilas		Co. Permit #		Notification # 9646582602		Completed 12-02-2024		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) WEBSTER WELL DRILLING INC				Lic. # 665		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.90669 °N -89.68015 °W				Method Code SCR006	
Address PO BOX 151 MINOCQUA WI 54548-0151				Well Plan Approval #		SW NE Section Township Range or Govt Lot # 36 40 N 6 E		2. Well Type New Well				of previous unique well #		constructed in	
Hicap Permanent Well #				Common Well #		Specific Capacity 1.5				Reason for replaced or reconstructed well ?				Construction Type Drilled	
3. Well serves 1 # of HOME						Hicap Well ? No		Private, potable						Hicap Property ? No	
Heat Exchange ___ # of drillholes						Hicap Potable ? No									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		43		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
Q Y C				Q-CAVING Y-SAND & GRAVEL C-CLAYEY				Surface		32					
M S				M-MEDIUM S-SAND				32		43					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level					
6		18.97 LBS. ASTM A53-B WHEATLAND WELDED JOINTS				Surface		40		20 ft. below ground surface					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is					
6		3' #10 SLOT STAINLESS STEEL SCREEN				40		43		12 in. above grade					
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		10. Pump Test					
GRANULAR BENTONITE				Surface		18		1 S		Developed ? Yes Disinfected ? Yes Capped ? Yes					
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller								Lic #		Date Signed					
MND								4634		12-09-2024					
Drill Rig Operator								Lic or Reg #		Date Signed					

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 12-09-2024

Updated On: 12-30-2024

Review Status: APPROVED