

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACA935		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner STEWART WATSON						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 1006 ROOSTER RUN						Town of ST. GERMAIN						1787					
City MIDDLETON						State WI		Zip Code 53562				Street Address or Road Name and Number FOREST DRIVE					
County Vilas		Co. Permit #		Notification # 9529948401		Completed 12-12-2024		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) WEBSTER WELL DRILLING INC				Lic. # 665		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.93593 °N -89.49445 °W				Method Code SCR006			
Address PO BOX 151 MINOCQUA WI 54548-0151				Well Plan Approval #		SW NE Section Township Range or Govt Lot # 21 40 N 8 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 0.7													
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		33		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				Q X Q-CAVING X-SAND & CLAY M S M-MEDIUM S-SAND		Surface 28		28 33			
6. Casing, Liner, Screen												8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 4 ft. below ground surface				11. Well Is 12 in. above grade			
6		18.97 LBS. ASTM A53-B WHEATLAND WELDED JOINTS				Surface		30		10. Pump Test Pumping level 25 ft. below surface Pumping at 15 GP M for 1 Hrs. Pumping Method ? Test Pump				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
6		3' #10 SLOT STAINLESS STEEL SCREEN				30		33									
7. Grout or Other Sealing Material Method MOUNDED												12. Notified Owner of need to fill & seal ? No					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No							
GRANULAR BENTONITE				Surface		18		1 S									
13. Constructor / Supervisory Driller												Lic #		Date Signed			
MND												4634		12-16-2024			
Drill Rig Operator												Lic or Reg #		Date Signed			
MND												4634		12-16-2024			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	=	75	Septic or Holding, or POWTS Tank	=	55

Comment:

Created On: 12-16-2024

Updated On: 01-03-2025

Review Status: APPROVED