Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACB416

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: VOIGT, JEFF	Phone #
Mailing Address: W6549 27TH ST	
City: NECEDAH	State: WI — Zip Code: 54646
County: Juneau	Co. Permit #: — Notification #: 9749844601 — Completed: 12-20-2024
Well Constructor (Business Name): MARESCH, JACOB J	Lic. #: 7588 — Facility ID # (Public Wells):
Address: W5250 WILEY LANE, NEW LISBON WI 53950	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 5

1. Well Location

Town of NECEDAH				Fire # (if avail.): W6549
Street Address or Road Name and Number: 27TH ST				
Subdivision Name			Lot #	Block #
Latitude / Longitude in Decimal Degree (DD): 43.98326 °N -90.09355 °W				Method Code: SCR002
SE	SE	Section: 35	Township: 18 N	Range: 3 E
or Govt Lot #				

2. Well Type New Well
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?
Construction Type: Driven Point

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
1.25	Surface	31

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	E	S	S	T-TAN/BROWN E-CLEAN S-SAND S-SANDY	Surface	31

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
1.25	GALVINIZED STEEL THREADED COUPLINGS ASTM A53	Surface	28
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	JOHNSON STAINLESS STEEL 10 SLOTT	28	31

9. Static Water Level
8 ft. below ground surface

10. Pump Test
Pumping level 10 ft. below surface
Pumping at 10 GP M for 1 Hrs.
Pumping Method ? Test Pump

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JM	7588	01-25-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 01-18-2025 Updated On: 01-27-2025 Review Status: APPROVED