Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACB470

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: RMS GROUP - CHRIS CYBUL	Phone #: (184)748-9335
Mailing Address: PO BOX 172	
City: ANTIOCH	State: IL — Zip Code: 60002
County: Kenosha	Co. Permit #:
Notification #: 9688592401	Completed: 12-30-2024
Well Constructor (Business Name): BOYCE, KENNETH D	Lic. #: 6123
Facility ID # (Public Wells):	
Well Plan Approval #: 96885924	
Address: BEACH PUMP & WELL SERV INC 10453 W BOYCE LN, BEACH PARK IL 60087	
Approval Date (mm-dd-yyyy): 11-19-2024	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1	

1. Well Location

Village of SALEM LAKES	Fire # (if avail.):
Street Address or Road Name and Number: 10433 W 266TH AVE	
Subdivision Name: SUNSET OAKS MANOR	Lot #: 262 — Block #:
Latitude / Longitude in Decimal Degree (DD): 42.52373 °N -88.13063 °W	Method Code: SCR002

NE	NE	Section	Township	Range
or Govt Lot #		28	1 N	20 E

2. Well Type New Well
of previous unique well #: — constructed in: 2024
Reason for replaced or reconstructed well ?:
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	9
5	9	85

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 5in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		F		F-FILL	Surface	2
Y		C		Y-YELLOW C-CLAY	2	14
G		C		G-GRAY C-CLAY	14	53
		G		G-GRAVEL/STONES	53	54
	A	S		A-COARSE S-SAND	54	59
		G	S	G-GRAVEL/STONES S-SANDY	59	62
R		C		R-RED C-CLAY	62	80
		S		S-SAND	80	85

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	ASTM A-53 BT/C WHEATLAND - COUPLING ASSEMBLY	Surface	82
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	5" TELE STAINLESS SLOT # 15, SAND	82	85

7. Grout or Other Sealing Material

Method GROUT DISPLACEMENT (PLUG)

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	9	3 S

9. Static Water Level
30 ft. below ground surface

10. Pump Test
Pumping level 40 ft. below surface
Pumping at 10 GP M for 4 Hrs.
Pumping Method ? Test Pump

11. Well Is
15 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
KB	6123	01-24-2025
Drill Rig Operator	Lic or Reg #	Date Signed
KB	6123	01-24-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 01-24-2025 Updated On: 10-15-2026 Review Status: APPROVED