

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACB802		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner TOWN OF ST. GERMAIN						Phone # (715)477-2205		1. Well Location				Fire # (if avail.)					
Mailing Address PO BOX 7						Town of ST. GERMAIN											
City ST. GERMAIN						State WI		Zip Code 54558				Street Address or Road Name and Number 553 WI-155					
County Vilas		Co. Permit #		Notification #		Completed 09-25-2024		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) MUNICIPAL WELL & PUMP/MIDWEST WELL				Lic. # 13		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.9148 °N -89.4888 °W							
Address 1212 STORBECK DR WAUPUN WI 53963				Well Plan Approval #		SE SE		Section 28		Township 40 N		Method Code SCR002 Range 8 E					
				Approval Date (mm-dd-yyyy)		or Govt Lot #											
Hicap Permanent Well # 95497		Common Well #		Specific Capacity 0		2. Well Type Replacement of previous unique well # ME902 constructed in 1997											
Reason for replaced or reconstructed well ? WELL FAILED																	
3. Well serves 1 # of FIRE DEPARTMENT Private, non-potable Heat Exchange ___ # of drillholes				Hicap Well ? Yes Hicap Property ? Yes Hicap Potable ? No		Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
24		Surface		90		No Rotary - Mud Circulation		No		M S		M-MEDIUM S-SAND		Surface		15	
						No Rotary - Air		No		M Y Z		M-MEDIUM Y-SAND & GRAVEL Z- W/COBBLES/BOULDERS		15		25	
						No Rotary - Air & Foam		No		N S		N-FINE S-SAND		25		35	
						No Drill-Through Casing Hammer				A Y Z		A-COARSE Y-SAND & GRAVEL Z- W/COBBLES/BOULDERS		35		40	
						No Reverse Rotary				N S		N-FINE S-SAND		40		90	
						No Cable-tool Bit ___ in. dia...		No									
						Yes Dual Rotary		No									
						Yes Temp. Outer Casing 24in. dia											
						Yes Removed? 90depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 30 ft. below ground surface				11. Well Is 24 in. above grade			
16		CARBON STEEL, 0.375", ASTM A53 GRADE B, AXIS PIPE & TUBE M&M IN USA, WELDED				Surface		60		10. Pump Test Pumping level 72 ft. below surface Pumping at 618 GP M for 1 Hrs. Pumping Method ? Test Pump				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
16		JOHNSON 304 SS PIPE SIZE WELL SCREEN, 20 SLOT, HIQ, 1000' CONSTRUCTION, WELDED				60		90									
7. Grout or Other Sealing Material Method TREMIE PIPE - PUMPED												12. Notified Owner of need to fill & seal ? Yes					
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? Yes									
NEAT CEMENT GROUT		Surface		46		6 Y											
SAND SEAL		46		50		14 S											
GRAVEL PACK RED FLINT #20 WELL SLOT		50		90		80 S											
13. Constructor / Supervisory Driller				Lic #		Date Signed											
MR				7819		03-19-2025											
Drill Rig Operator				Lic or Reg #		Date Signed											
MR				7819		03-19-2025											

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 02-12-2025

Updated On: 03-20-2025

Review Status: APPROVED