Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACB802

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TOWN OF ST. GERMAIN			Phone #: (715)477-2205
Mailing Address: PO BOX 7			
City: ST. GERMAIN	State: WI	Zip Code: 54558	
County: Vilas	Co. Permit #:	Notification #:	Completed: 09-25-2024

Well Constructor (Business Name): MUNICIPAL WELL & PUMP/MIDWEST WELL	Lic. #: 13	Facility ID # (Public Wells):	
Address: 1212 STORBECK DR WAUPUN WI 53963		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #: 95497	Common Well #:	Specific Capacity: 14.7	

1. Well Location

Town of ST. GERMAIN

Fire # (if avail.):

Street Address or Road Name and Number: 553 WI-155

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 45.9148 °N -89.4888 °W				Method Code: SCR002
SE SE or Govt Lot #	Section: 28	Township: 40 N	Range: 8 E	

2. Well Type Replacement

of previous unique well # ME902 constructed in 1997

Reason for replaced or reconstructed well ?: WELL FAILED

Construction Type: Drilled

3. Well serves 1 # of FIRE DEPARTMENT

Private, non-potable Miscellaneous

Heat Exchange____# of drillholes

Hicap Well ? Yes

Hicap Property ? Yes

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
24	Surface	90

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
Yes	Dual Rotary	No
Yes	Temp. Outer Casing 24in. dia	
Yes	Removed? 90depth ft. (If NO explain on back side)	

8. Geology

Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
M	S		M-MEDIUM S-SAND	Surface	15
M	Y	Z	M-MEDIUM Y-SAND & GRAVEL Z-W/COBBLES/BOULDERS	15	25
N	S		N-FINE S-SAND	25	35
A	Y	Z	A-COARSE Y-SAND & GRAVEL Z-W/COBBLES/BOULDERS	35	40
N	S		N-FINE S-SAND	40	90

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
16	CARBON STEEL, 0.375", ASTM A53 GRADE B, AXIS PIPE & TUBE M&M IN USA, WELDED	Surface	60
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
16	JOHNSON 304 SS PIPE SIZE WELL SCREEN, 20 SLOT, HIQ, 1000' CONSTRUCTION, WELDED	60	90

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	46	6 Y
SAND SEAL	46	50	14 S
GRAVEL PACK RED FLINT #20 WELL SLOT	50	90	80 S

9. Static Water Level

30 ft. below ground surface

10. Pump Test

Pumping level 72 ft. below surface

Pumping at 618 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
MR	7819	03-19-2025
Drill Rig Operator	Lic or Reg #	Date Signed
MR	7819	03-19-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 02-12-2025 Updated On: 10-15-2026 Review Status: APPROVED