

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACC318		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner ANDREW STICHMAN				Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address W4058 COUTY RD O						Town of BARRE				W4058	
City WEST SALEM				State WI		Zip Code 54669				Street Address or Road Name and Number	
County La Crosse				Co. Permit # 2024098		Notification # 9785572401				Completed 03-18-2025	
Well Constructor (Business Name) HOLLER, WAYNE				Lic. # 4668		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.84037 °N -91.10842 °W	
Address HOLLER PLUMBING & WELL DRILLING N2995 SMITH VALLEY RD LA CROSSE WI 54601-2935				Well Plan Approval #		Subdivision Name				Lot # Block #	
Hicap Permanent Well #				Common Well #		Specific Capacity 0				Method Code GPS008	
3. Well serves 1 # of HOME				Hicap Well ? No		NW NW Section Township Range or Govt Lot # 28 16 N 6 W				2. Well Type New Well	
Private,potable Drillhole				Hicap Property ? No		Reason for replaced or reconstructed well ?				of previous unique well # constructed in	
Heat Exchange ___ # of drillholes				Hicap Potable ? No		Construction Type Drilled				Reason for replaced or reconstructed well ?	
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes	
6		Surface		132		No Rotary - Mud Circulation		No		T S M S	
						No Rotary - Air		No		E S H S	
						No Rotary - Air & Foam		No		G S H S	
						No Drill-Through Casing Hammer				G H N N	
						No Reverse Rotary				Type, Caving/Noncaving, Color, Hardness, etc...	
						Yes Cable-tool Bit 6in. dia...		No		From (ft.) To (ft.)	
						No Dual Rotary		No		Surface 54	
						No Temp. Outer Casing ___in. dia				54 85	
						No Removed? ___depth ft. (If NO explain on back side)				85 108	
										108 132	
8. Geology											
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level	
6		ASTM-A53 .280 WALL WHEATLAND USA PLAIN END WELD				Surface		105		32 ft. below ground surface	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is	
										24 in. above grade	
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		10. Pump Test			
GRANULAR BENTONITE		Surface				5 S		Developed ? Yes			
12. Notified Owner of need to fill & seal ? No											
Filled & Sealed Well(s) as needed? No											
13. Constructor / Supervisory Driller											
MH		Lic #		Date Signed		7400		04-06-2025		11. Well Is	
Drill Rig Operator		Lic or Reg #		Date Signed		7400		04-06-2025		Disinfected ? Yes	
MH		7400		04-06-2025						Capped ? Yes	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		120	Building Drain - Sanitary		85
POWTS dispersal component (soil absorption unit or mound)		90	Landfill		1200
			Sewer - Building Sanitary		105

Comment:

Created On: 03-18-2025

Updated On: 04-22-2025

Review Status: APPROVED