# Well Construction Report
## *WISCONSIN UNIQUE WELL NUMBER* ACC318

**Drinking Water and Groundwater - DG/5**
**Department of Natural Resources, Box 7921**
**Madison WI 53707**
Form 3300-077A

| | |
|---|---|
| Property Owner: ANDREW STICHMAN | Phone # |
| Mailing Address: W4058 COUTY RD O | |
| City: WEST SALEM | State: WI — Zip Code: 54669 |
| County: La Crosse | Co. Permit #: 2024098 — Notification #: 9785572401 — Completed: 03-18-2025 |
| Well Constructor (Business Name): HOLLER, WAYNE | Lic. #: 4668 — Facility ID # (Public Wells) |
| Address: HOLLER PLUMBING & WELL DRILLING<br>N2995 SMITH VALLEY RD<br>LA CROSSE WI 54601-2935 | Well Plan Approval # — Approval Date (mm-dd-yyyy) |
| Hicap Permanent Well # | Common Well # — Specific Capacity: 0.2 |

**1. Well Location**

| | | | | |
|---|---|---|---|---|
| Town of BARRE | | | | Fire # (if avail.): W4058 |
| Street Address or Road Name and Number: COUNTY RD O | | | | |
| Subdivision Name | | | Lot # | Block # |
| Latitude / Longitude in Decimal Degree (DD): 43.84037 °N -91.10842 °W | | | | Method Code: GPS008 |
| NW NW or Govt Lot # | Section: 28 | Township: 16 N | Range: 6 W | |

**2. Well Type** New Well
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

**3. Well serves** 1 # of HOME
Private,potable — Drillhole
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

**4. Potential Contamination Sources - ON REVERSE SIDE**

**5. Drillhole Dimensions and Construction Method**

| Dia. (in.) | From (ft.) | To (ft.) |
|---|---|---|
| 6 | Surface | 132 |

| Upper Enlarged Drillhole | | Lower Open Bedrock |
|---|---|---|
| No | Rotary - Mud Circulation ..... | No |
| No | Rotary - Air ..... | No |
| No | Rotary - Air & Foam ..... | No |
| No | Drill-Through Casing Hammer | |
| No | Reverse Rotary | |
| Yes | Cable-tool Bit 6in. dia... | No |
| No | Dual Rotary ..... | No |
| No | Temp. Outer Casing ____in. dia | |
| No | Removed? ____depth ft. (If NO explain on back side) | |

**8. Geology**

| Geology Codes | | | | Type, Caving/Noncaving, Color, Hardness, etc... | From (ft.) | To (ft.) |
|---|---|---|---|---|---|---|
| T | S | M | S | T-TAN/BROWN S-SOFT/LOOSE M-SILT S-SANDY | Surface | 54 |
| E | S | H | S | E-GREEN S-SOFT/LOOSE H-SHALE S-SANDY | 54 | 85 |
| G | S | H | S | G-GRAY S-SOFT/LOOSE H-SHALE S-SANDY | 85 | 108 |
| G | H | N | N | G-GRAY H-HARD/FIRM N-SANDSTONE N-W/SANDSTONE | 108 | 132 |

**6. Casing, Liner, Screen**

| Dia. (in.) | Material, Weight, Specification Manufacturer & Method of Assembly | From (ft.) | To (ft.) |
|---|---|---|---|
| 6 | ASTM-A53 .280 WALL WHEATLAND USA PLAIN END WELD | Surface | 105 |
| Dia. (in.) | Screen type, material & slot size | From (ft.) | To (ft.) |
| | | | |

**9. Static Water Level**
32 ft. below ground surface

**10. Pump Test**
Pumping level 100 ft. below surface
Pumping at 14 GP M for 16 Hrs.
Pumping Method ? Test Pump

**11. Well Is**
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

**7. Grout or Other Sealing Material**
Method MOUNDED

| Kind of Sealing Material | From (ft.) | To (ft.) | # Sacks Cement |
|---|---|---|---|
| GRANULAR BENTONITE | Surface | | 5 S |

**12.** Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

| 13. Constructor / Supervisory Driller | Lic # | Date Signed |
|---|---|---|
| MH | 7400 | 04-06-2025 |
| Drill Rig Operator | Lic or Reg # | Date Signed |
| MH | 7400 | 04-06-2025 |

**4a. Potential Contamination Sources** Is the well located in floodplain ? No

| Type | Qualifier | Distance | Type | Qualifier | Distance |
|---|---|---|---|---|---|
| POWTS holding component (also known as holding tank) | | 120 | Building Drain - Sanitary | | 85 |
| POWTS dispersal component (soil absorption unit or mound) | | 90 | Landfill | | 1200 |
| | | | Sewer - Building Sanitary | | 105 |

Comment:

Created On: 03-18-2025 Updated On: 10-15-2026 Review Status: APPROVED