

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACC470		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner ECONOMY, ALEXANDRA						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address W3779 STATE ROAD 23						Town of PACKWAUKEE						W6194			
City MONTELLO						State WI		Zip Code 53949				Street Address or Road Name and Number LAKE STREET			
County Marquette		Co. Permit #		Notification # 9790481701		Completed 04-03-2025		Subdivision Name BUFFALO SHORES				Lot # 15 Block # 13			
Well Constructor (Business Name) FARAGO PLBG & TRENCHING INC				Lic. # 126		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.73765 °N -89.46996 °W				Method Code GPS008	
Address 229 SHORT ST PLAINFIELD WI 54966				Well Plan Approval #		NE SE		Section 31		Township 15 N		Range 9 E			
				Approval Date (mm-dd-yyyy)		or Govt Lot #									
Hicap Permanent Well #		Common Well #		Specific Capacity 0.7		2. Well Type New Well						of previous unique well #		constructed in	
3. Well serves 1 # of HOME				Hicap Well ? No		Reason for replaced or reconstructed well ?						Construction Type Drilled			
Private, potable				Hicap Property ? No											
Heat Exchange ___ # of drillholes				Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		102		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>Yes</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)					
		F		F-FILL				Surface		10					
		C		C-CLAY				10		22					
		Y		Y-SAND & GRAVEL				22		102					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		IPSCO A53 6.625 X.280 WALL WELDED TOGETHER WEIGHT 1897.00				Surface		100							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
6		OPEN HOLE				100		102							
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
BENT ALONG CASING				Surface				4							
9. Static Water Level															
30 ft. below ground surface															
10. Pump Test															
Pumping level 60 ft. below surface															
Pumping at 20 GP M for 1 Hrs.															
Pumping Method ? Airlift															
11. Well Is															
36 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller															
Lic #				Date Signed											
TF				41				04-07-2025							
Drill Rig Operator				Lic or Reg #				Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		87	POWTS dispersal component (soil absorption unit or mound)		78

Comment:

Created On: 03-27-2025

Updated On: 04-22-2025

Review Status: APPROVED