

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACC623		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner CHRISTIANSON, NATHAN						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address N4290 KRAUSE RD						Town of BANGOR						N4290							
City BANGOR						State WI		Zip Code 54614				Street Address or Road Name and Number N4290 KRAUSE RD							
County La Crosse		Co. Permit # 2025006		Notification # 9754107101		Completed 01-24-2025		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) LYSAKER, DAVID LLOYD				Lic. # 8130		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.8759 °N -90.9665 °W				Method Code SCR002					
Address 11982 SOUTH ST TREMPEALEAU WI 54661				Well Plan Approval #		NW SW		Section 10		Township 16 N		Range 5 W		or Govt Lot #					
Approval Date (mm-dd-yyyy)				Heat Exchange ___ # of drillholes		Hicap Well ? No Hicap Property ? No Hicap Potable ? No				2. Well Type Replacement of previous unique well # QV600 constructed in 2003 Reason for replaced or reconstructed well ? COLLAPSED BEDROCK Construction Type Drilled									
Hicap Permanent Well #		Common Well #		Specific Capacity 0															
3. Well serves 1 # of HOME Private, potable																			
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		20		No Rotary - Mud Circulation				No		T S S		T-TAN/BROWN S-SOFT/LOOSE S-SAND		Surface		10	
8		20		102		No Rotary - Air				No		T M N		T-TAN/BROWN M-MEDIUM N-SANDSTONE		10		97	
6		102		144		No Rotary - Air & Foam				No		T H N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE		97		144	
						No Drill-Through Casing Hammer													
						No Reverse Rotary													
						Yes Cable-tool Bit 10in. dia...				No									
						No Dual Rotary				No									
						Yes Temp. Outer Casing 10in. dia													
						Yes Removed? 18depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		80 ft. below ground surface				14 in. above grade					
6		NEW P.E. BLACK STEEL, .280WALL, 18.97#, ASTM A53B, IPSCO, WELDED				Surface		102		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 126 ft. below surface Pumping at 18 GP M for 12 Hrs. Pumping Method ? Test Pump									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? Yes							
Method TREMIE PIPE - PUMPED												Filled & Sealed Well(s) as needed? Yes							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed			
NEAT CEMENT GROUT				Surface		102		28 S		DL				8130		01-24-2025			
												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		55	Building Drain - Sanitary		25
POWTS dispersal component (soil absorption unit or mound)		75	Sewer - Building Sanitary		45

Comment:

Created On: 04-06-2025

Updated On: 04-22-2025

Review Status: APPROVED