Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACC877

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	ROUSE, ROBERT & CHERYL GROSS
Phone #	
Mailing Address	117 W. DIVISION STREET
City	HANCOCK
State	WI
Zip Code	54943
County	Waushara
Co. Permit #	
Notification #	9842986701
Completed	05-05-2025
Well Constructor (Business Name)	FARAGO PLBG & TRENCHING INC
Lic. #	126
Facility ID # (Public Wells)	
Address	229 SHORT ST PLAINFIELD WI 54966
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	20

1. Well Location

Village of HANCOCK	Fire # (if avail.) 117
Street Address or Road Name and Number	W. DIVISION STREET
Subdivision Name	CSM 0109
Lot #	1
Block #	
Latitude / Longitude in Decimal Degree (DD)	44.12775 °N -89.52824 °W
Method Code	GPS008
SW SE or Govt Lot #	
Section	10
Township	19 N
Range	8 E

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

NO WATER

Construction Type Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	56

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	S-SAND	Surface	10
Y	Y-SAND & GRAVEL	10	56

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	IPSCO A53 6.625 X.280 WALL WELDED TOGETHER WEIGHT 986.44	Surface	52
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	#10 ALLOY S&S	52	56

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENT ALONG CASING	Surface		

9. Static Water Level

24 ft. below ground surface

10. Pump Test

Pumping level 25 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
CF	8145	05-15-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Drain - Sanitary		25

Comment:

Created On: 04-17-2025 Updated On: 10-15-2026 Review Status: APPROVED