

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACC877		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner ROUSE, ROBERT & CHERYL GROSS						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 117 W. DIVISION STREET								Village of HANCOCK				117							
City HANCOCK						State WI		Zip Code 54943				Street Address or Road Name and Number W. DIVISION STREET							
County Waushara		Co. Permit #		Notification # 9842986701		Completed 05-05-2025		Subdivision Name CSM 0109				Lot # 1		Block #					
Well Constructor (Business Name) FARAGO PLBG & TRENCHING INC				Lic. # 126		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.12775 °N -89.52824 °W				Method Code GPS008					
Address 229 SHORT ST PLAINFIELD WI 54966				Well Plan Approval #		SW SE		Section 10		Township 19 N		Range 8 E							
				Approval Date (mm-dd-yyyy)		or Govt Lot #													
Hicap Permanent Well #		Common Well #		Specific Capacity 0		2. Well Type Replacement				of previous unique well # constructed in									
3. Well serves 1 # of HOME				Hicap Well ? No		Reason for replaced or reconstructed well ? NO WATER													
Private, potable				Hicap Property ? No															
Heat Exchange ___ # of drillholes				Hicap Potable ? No		Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		56		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>Yes</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)						S		S-SAND		Surface		10	
												Y		Y-SAND & GRAVEL		10		56	
6. Casing, Liner, Screen														9. Static Water Level		11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		24 ft. below ground surface				24 in. above grade					
6		IPSCO A53 6.625 X.280 WALL WELDED TOGETHER WEIGHT 986.44				Surface		52		10. Pump Test Pumping level 25 ft. below surface Pumping at 20 GP M for 1 Hrs. Pumping Method ? Test Pump				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
6		#10 ALLOY S&S				52		56											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? Yes					
Method MOUNDED																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? Yes									
BENT ALONG CASING				Surface															
13. Constructor / Supervisory Driller														Lic #		Date Signed			
CF														8145		05-15-2025			
Drill Rig Operator														Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Drain - Sanitary		25

Comment:

Created On: 04-17-2025

Updated On: 05-27-2025

Review Status: APPROVED