Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACC947

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: DERHEIM, MICHAEL	Phone #
Mailing Address: 1113 WEST BONE LAKE TRL	
City: MILLTOWN	State: WI — Zip Code: 54858

County	Co. Permit #	Notification #	Completed
Polk	9833924902	9833924902	04-22-2025

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
FRITZ, ROBERT R	7473	

Address: W6656 340TH AVE, ELLSWORTH WI 54011

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well # | Common Well # | Specific Capacity: 0.4

1. Well Location

Town of GEORGETOWN | Fire # (if avail.): 2139

Street Address or Road Name and Number: WEST BONE LAKE LN

Subdivision Name | Lot # | Block #

Latitude / Longitude in Decimal Degree (DD): 45.51734 °N -92.38937 °W | Method Code: SCR002

NE SE or Govt Lot #	Section	Township	Range
	18	35 N	16 W

2. Well Type New Well

of previous unique well # | constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable | Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	84
4	84	92

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	Y	G	T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL G-W/GRAVEL/STONES	Surface	92

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	STEEL 10.79 A53B WHEATLAND WELDED	Surface	84
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
2	STAINLESS STEEL, JOHNSON 12 SLOT	84	92

7. Grout or Other Sealing Material

Method: TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	84	5 S

9. Static Water Level

3 ft. below ground surface

10. Pump Test

Pumping level 50 ft. below surface

Pumping at 20 GP M for 3 Hrs.

Pumping Method ? Airlift

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
RF	7473	05-21-2025
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RF	7473	05-21-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 04-21-2025 Updated On: 06-05-2025 Review Status: APPROVED