

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACC947		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner DERHEIM, MICHAEL				Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 1113 WEST BONE LAKE TRL						Town of GEORGETOWN				2139	
City MILLTOWN				State WI		Zip Code 54858				Street Address or Road Name and Number WEST BONE LAKE LN	
County Polk		Co. Permit # 9833924902		Notification # 9833924902		Completed 04-22-2025		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) FRITZ, ROBERT R				Lic. # 7473		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.51734 °N -92.38937 °W		Method Code SCR002	
Address W6656 340TH AVE ELLSWORTH WI 54011				Well Plan Approval #		NE SE Section Township Range or Govt Lot # 18 35 N 16 W		2. Well Type New Well			
Hicap Permanent Well #				Common Well #		Specific Capacity 0.4		of previous unique well # constructed in			
3. Well serves 1 # of HOME				Hicap Well ? No		Reason for replaced or reconstructed well ?					
Private, potable Drillhole				Hicap Property ? No		Construction Type Drilled					
Heat Exchange ___ # of drillholes				Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes	
8		Surface		84		Yes Rotary - Mud Circulation		No		T Q Y G	
4		84		92		No Rotary - Air		No		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL G-W/GRAVEL/STONES	
						No Rotary - Air & Foam		No			
						No Drill-Through Casing Hammer					
						No Reverse Rotary					
						No Cable-tool Bit ___ in. dia...		No			
						No Dual Rotary		No			
						No Temp. Outer Casing ___ in. dia					
						No Removed? ___ depth ft. (If NO explain on back side)					
8. Geology											
Type, Caving/Noncaving, Color, Hardness, etc...											
From (ft.) To (ft.) Surface 92											
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 3 ft. below ground surface	
4		STEEL 10.79 A53B WHEATLAND WELDED				Surface		84		11. Well Is 24 in. above grade	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Developed ? Yes	
2		STAINLESS STEEL, JOHNSON 12 SLOT				84		92		Disinfected ? Yes	
7. Grout or Other Sealing Material											
Method TREMIE PIPE - PUMPED											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		Pumping level 50 ft. below surface			
GRANULAR BENTONITE		Surface		84		5 S		Pumping at 20 GP M for 3 Hrs.			
Filled & Sealed Well(s) as needed? No											
13. Constructor / Supervisory Driller											
Lic #		Date Signed									
RF		7473		05-21-2025							
Drill Rig Operator											
Lic or Reg #		Date Signed									
RF		7473		05-21-2025							

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 04-21-2025

Updated On: 06-05-2025

Review Status: APPROVED