Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACC949

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TAYLOR, DEREK			Phone #
Mailing Address: 5318 1230TH ST			
City: PRESCOTT	State: WI	Zip Code: 54021	
County: Pierce	Co. Permit #: 9777376801	Notification #: 9777376801	Completed: 03-16-2025

1. Well Location

City of PRESCOTT | Fire # (if avail.): 5318

Street Address or Road Name and Number: 1230TH ST

Subdivision Name | Lot # | Block #

Well Constructor (Business Name): FRITZ, ROBERT R	Lic. #: 7473	Facility ID # (Public Wells)	Latitude / Longitude in Decimal Degree (DD): 44.73229 °N -92.75414 °W	Method Code: SCR002

Address: W6656 340TH AVE, ELLSWORTH WI 54011

Well Plan Approval #

Approval Date (mm-dd-yyyy)

NE	NW	Section	Township	Range
or Govt Lot #		24	26 N	20 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Hicap Permanent Well #	Common Well #	Specific Capacity: 0.3

3. Well serves 1 # of HOME

Private,potable | Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	84
6	84	380

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
Yes	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	V	C	C	T-TAN/BROWN V-NON-CAVING C-CLAY C-CLAYEY	Surface	7
Y	V	L	L	Y-YELLOW V-NON-CAVING L-LIMESTONE/DOLOMITE L-LIMEY OR DOLOMITIC	7	275
T	V	N	N	T-TAN/BROWN V-NON-CAVING N-SANDSTONE N-W/SANDSTONE	275	380

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 18.79 A53B WHEATLAND, WELDED	Surface	84
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

278 ft. below ground surface

10. Pump Test

Pumping level 340 ft. below surface

Pumping at 20 GP M for 3 Hrs.

Pumping Method ? Airlift

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	84	1 Y

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
RF	7473	05-21-2025
Drill Rig Operator	Lic or Reg #	Date Signed
RF	7473	05-21-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 04-21-2025 Updated On: 06-05-2025 Review Status: APPROVED