

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACC949		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner TAYLOR, DEREK						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 5318 1230TH ST								City of PRESCOTT				5318					
City PRESCOTT						State WI		Zip Code 54021				Street Address or Road Name and Number 1230TH ST					
County Pierce		Co. Permit # 9777376801		Notification # 9777376801		Completed 03-16-2025		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) FRITZ, ROBERT R				Lic. # 7473		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.73229 °N -92.75414 °W				Method Code SCR002					
Address W6656 340TH AVE ELLSWORTH WI 54011				Well Plan Approval #		NE NW Section Township Range or Govt Lot # 24 26 N 20 W		2. Well Type New Well				of previous unique well # constructed in					
Hicap Permanent Well #		Common Well #		Specific Capacity 0.3		Reason for replaced or reconstructed well ?		Construction Type Drilled				Reason for replaced or reconstructed well ?					
3. Well serves 1 # of HOME				Hicap Well ? No		Private, potable Drillhole		Hicap Property ? No		Heat Exchange ___ # of drillholes		Hicap Potable ? No					
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		84		No Rotary - Mud Circulation		No		T V C C		T-TAN/BROWN V-NON-CAVING C-CLAY C-CLAYEY		Surface		7	
6		84		380		No Rotary - Air		No		Y V L L		Y-YELLOW V-NON-CAVING L-LIMESTONE/DOLOMITE L-LIMEY OR DOLOMITIC		7		275	
						Yes Rotary - Air & Foam		No		T V N N		T-TAN/BROWN V-NON-CAVING N-SANDSTONE N-W/SANDSTONE		275		380	
						No Drill-Through Casing Hammer											
						No Reverse Rotary											
						No Cable-tool Bit ___ in. dia...		No									
						No Dual Rotary		No									
						No Temp. Outer Casing ___ in. dia											
						No Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 278 ft. below ground surface				11. Well Is 18 in. above grade			
6		STEEL 18.79 A53B WHEATLAND, WELDED				Surface		84		10. Pump Test Pumping level 340 ft. below surface Pumping at 20 GP M for 3 Hrs. Pumping Method ? Airlift				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
7. Grout or Other Sealing Material Method TREMIE PIPE - PUMPED												12. Notified Owner of need to fill & seal ? No					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No							
NEAT CEMENT GROUT				Surface		84		1 Y									
13. Constructor / Supervisory Driller												Lic #		Date Signed			
RF												7473		05-21-2025			
Drill Rig Operator												Lic or Reg #		Date Signed			
RF												7473		05-21-2025			

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 04-21-2025

Updated On: 06-05-2025

Review Status: APPROVED