

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACD040		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner BARBER, MARK						Phone # (507)429-4470		1. Well Location				Fire # (if avail.)							
Mailing Address 27492 SIEVERS DR						Town of WEBB LAKE													
City RUSHFORD						State MN		Zip Code 55971				Street Address or Road Name and Number SPRING COURT AT LAKELAND							
County Burnett		Co. Permit #		Notification # 9848796701		Completed 04-23-2025		Subdivision Name RIDGE TRACE ADDITION TO VOYAGER VILLAGE				Lot # 1		Block #					
Well Constructor (Business Name) ARNOLD, WILLIAM JR				Lic. # 4514		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.99952 °N -92.16961 °W				Method Code GPS008					
Address BILL ARNOLD PUMP & WELL 28290 STATE RD 35 DANBURY WI 54830				Well Plan Approval #		Approval Date (mm-dd-yyyy)		SW SW Section Township Range or Govt Lot # 30 41 N 14 W		2. Well Type New Well				of previous unique well # constructed in					
Hicap Permanent Well #		Common Well #		Specific Capacity		Reason for replaced or reconstructed well ?													
3. Well serves 1 # of CAMPER						Hicap Well ? No		Private,potable				Hicap Property ? No		Heat Exchange ___ # of drillholes					
						Hicap Potable ? No		Construction Type Driven Point											
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method										8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
2		Surface		45		No Rotary - Mud Circulation				No		T Q Y M		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL M-SILTY		Surface		45	
						No Rotary - Air				No									
						No Rotary - Air & Foam				No									
						No Drill-Through Casing Hammer													
						No Reverse Rotary													
						No Cable-tool Bit ___ in. dia...				No									
						No Dual Rotary				No									
						No Temp. Outer Casing ___ in. dia													
						No Removed? ___depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen																			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)											
2		GALV. STEEL SCH 40 ASTM A53 THREADED AND COUPLED				Surface		41											
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
2		SIMMONS 1753-1 60GA STAINLESS				41		45											
7. Grout or Other Sealing Material																			
Method MOUNDED																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement											
GRANULAR BENTONITE				Surface				1 S											

9. Static Water Level

31 ft. below ground surface

10. Pump Test

Pumping level 31 ft. below surface

Pumping at 8 GP M for 1 Hrs.

Pumping Method ? Other

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

No

Filled & Sealed Well(s) as needed?

No

13. Constructor / Supervisory Driller

Lic #

Date Signed

WA

4514

04-25-2025

Drill Rig Operator

Lic or Reg #

Date Signed

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		85	POWTS dispersal component (soil absorption unit or mound)		95

Comment:

Created On: 04-23-2025

Updated On: 05-06-2025

Review Status: APPROVED