Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACD040

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: BARBER, MARK		Phone #: (507)429-4470
Mailing Address: 27492 SIEVERS DR		
City: RUSHFORD	State: MN	Zip Code: 55971

County	Co. Permit #	Notification #	Completed
Burnett		9848796701	04-23-2025

1. Well Location

Town of WEBB LAKE

Fire # (if avail.):

Street Address or Road Name and Number: SPRING COURT AT LAKELAND

Subdivision Name	Lot #	Block #
RIDGE TRACE ADDITION TO VOYAGER VILLAGE	1	

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
ARNOLD, WILLIAM JR	4514	

Address: BILL ARNOLD PUMP & WELL 28290
STATE RD 35
DANBURY WI 54830

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Latitude / Longitude in Decimal Degree (DD)				Method Code
45.99952 °N	-92.16961 °W			GPS008

SW	SW	Section	Township		Range	
or Govt Lot #		30	41	N	14	W

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Hicap Permanent Well #	Common Well #	Specific Capacity

3. Well serves 1 # of CAMPER

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

Construction Type: Driven Point

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	45

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	Y	M	T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL M-SILTY	Surface	45

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	GALV. STEEL SCH 40 ASTM A53 THREADED AND COUPLED	Surface	41
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
2	SIMMONS 1753-1 60GA STAINLESS	41	45

7. Grout or Other Sealing Material

Method: MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1 S

9. Static Water Level	11. Well Is	
31 ft. below ground surface	18 in. above grade	
10. Pump Test	Developed ?	Yes
Pumping level 31 ft. below surface	Disinfected ?	Yes
Pumping at 8 GP M for 1 Hrs.	Capped ?	Yes
Pumping Method ? Other		

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
WA	4514	04-25-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		85	POWTS dispersal component (soil absorption unit or mound)		95

Comment:

Created On: 04-23-2025 Updated On: 05-06-2025 Review Status: APPROVED