Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACD314

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: BRIAN S OLSON		Phone #
Mailing Address: 1684 CYPRESS AVE		
City: ARKDALLE	State: WI	Zip Code: 54613

County	Co. Permit #	Notification #	Completed
Adams			04-09-2025

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
ROBERTS IRRIGATION CO INC	3262	

Address: 1500 POST RD
PLOVER WI 54467

Well Plan Approval #: 01-01-0324
Approval Date (mm-dd-yyyy): 04-09-2025

Hicap Permanent Well #	Common Well #	Specific Capacity
95618		28.2

3. Well serves 1 # of CENTER PIVOT
Private, non-potable — Irrigation
Heat Exchange____# of drillholes

Hicap Well ? Yes
Hicap Property ? Yes
Hicap Potable ? No

1. Well Location
Town of STRONGS PRAIRIE

Fire # (if avail.)

Street Address or Road Name and Number
NORTH OF CUMBERLAND DR ----- EAST OF 17TH AVE

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
44.0177 °N	-89.9061 °W			GPS008

SW NE or Govt Lot #	Section	Township	Range
	21	18 N	5 E

2. Well Type Reconstruction
of previous unique well # WQ610 constructed in 2011

Reason for replaced or reconstructed well ?
SCREEN KEPT PLUGGING

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
16	Surface	236

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
Yes	Dual Rotary	Yes
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
I	M	Y		I-WHITE M-MEDIUM Y-SAND & GRAVEL	Surface	81
I	S	N		I-WHITE S-SOFT/LOOSE N-SANDSTONE	81	85
I	H	N		I-WHITE H-HARD/FIRM N-SANDSTONE	85	236

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
16	ASTM A53B .375 STEEL WELDED #62.5 PRFT	Surface	88
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	88	2 S

9. Static Water Level
20.3 ft. below ground surface

10. Pump Test
Pumping level 26.5 ft. below surface
Pumping at 175 GP M for 2 Hrs.
Pumping Method ? Other

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RICI		05-04-2025
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
GB	9368	05-04-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 05-04-2025 Updated On: 10-15-2026 Review Status: APPROVED