Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACE009

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: SCIOTO PROPERTIES SP-16 LLC			Phone #
Mailing Address: W491 OAKWOOD BEACH RD			
City: MARINETTE	State: WI	Zip Code: 54143	
County: Marinette	Co. Permit #:	Notification #: 9839928904	Completed: 09-25-2025

Well Constructor (Business Name): STEFFL DRILLING & PUMP INC	Lic. #: 7843	Facility ID # (Public Wells):	
Address: 2295 66TH AVE NE WILMAR MN 56201		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.3	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location
Town of PESHTIGO
Fire # (if avail.): W491
Street Address or Road Name and Number: OAKWOOD BEACH RD
Subdivision Name:
Lot #:
Block #:
Latitude / Longitude in Decimal Degree (DD): 45.06701 °N -87.61909 °W
Method Code: GPS008
SW SW or Govt Lot #
Section: 17
Township: 30 N
Range: 24 E

2. Well Type Replacement
of previous unique well #
constructed in
Reason for replaced or reconstructed well ?
CONTAMINATION
Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	182
5.95	182	638

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	Yes
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K	S	I		K-BLACK S-SOFT/LOOSE I-SOIL-ORGANIC	Surface	1
T	S	S		T-TAN/BROWN S-SOFT/LOOSE S-SAND	1	26
T	A	C	G	T-TAN/BROWN A-COARSE C-CLAY G-W/GRAVEL/STONES	26	83
T	M	C		T-TAN/BROWN M-MEDIUM C-CLAY	83	106
G	H	L		G-GRAY H-HARD/FIRM L-LIMESTONE/DOLOMITE	106	299
I	M	N		I-WHITE M-MEDIUM N-SANDSTONE	299	349
G	S	H		G-GRAY S-SOFT/LOOSE H-SHALE	349	358
G	H	L		G-GRAY H-HARD/FIRM L-LIMESTONE/DOLOMITE	358	454
R	H	H		R-RED H-HARD/FIRM H-SHALE	454	458
T	H	L		T-TAN/BROWN H-HARD/FIRM L-LIMESTONE/DOLOMITE	458	462
R	H	H		R-RED H-HARD/FIRM H-SHALE	462	465
T	H	L		T-TAN/BROWN H-HARD/FIRM L-LIMESTONE/DOLOMITE	465	471
I	H	N		I-WHITE H-HARD/FIRM N-SANDSTONE	471	473
T	H	L		T-TAN/BROWN H-HARD/FIRM L-LIMESTONE/DOLOMITE	473	574
R	H	H		R-RED H-HARD/FIRM H-SHALE	574	575
T	H	L		T-TAN/BROWN H-HARD/FIRM L-LIMESTONE/DOLOMITE	575	613
I	H	N		I-WHITE H-HARD/FIRM N-SANDSTONE	613	637
G	H	L		G-GRAY H-HARD/FIRM L-LIMESTONE/DOLOMITE	637	638

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL	Surface	182
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method GROUTING - NEAT CEMENT

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	182	58 S

9. Static Water Level

11.4 ft. below ground surface

10. Pump Test

Pumping level 61 ft. below surface

Pumping at 14 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
MJS	6637	10-01-2025
Drill Rig Operator	Lic or Reg #	Date Signed
AK	8951	10-01-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 05-22-2025 Updated On: 10-15-2026 Review Status: APPROVED