

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACE011		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner SCIOTO PROPERTIES SP-16 LLC						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address W454 OAKWOOD BEACH RD						Town of PESHTIGO						W454			
City MARINETTE						State WI		Zip Code 54143				Street Address or Road Name and Number OAKWOOD BEACH RD			
County Marinette		Co. Permit #		Notification # 9839928905		Completed 09-25-2025		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) STEFFL DRILLING & PUMP INC				Lic. # 7843		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.06764 °N -87.61673 °W				Method Code GPS008	
Address 2295 66TH AVE NE WILMAR MN 56201				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 17 30 N 24 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? CONTAMINATION Construction Type Drilled							
				Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #		Common Well #		Specific Capacity 0											
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method												8. Geology			
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock			Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)		
10 Surface 181			Yes Rotary - Mud Circulation			No			K S I		K-BLACK S-SOFT/LOOSE I-SOIL-ORGANIC		Surface 1		
5.89 181 566			Yes Rotary - Air			Yes			T S S G		T-TAN/BROWN S-SOFT/LOOSE S-SAND G-W/GRAVEL/STONES		1 30		
			No Rotary - Air & Foam			No			T S S C		T-TAN/BROWN S-SOFT/LOOSE S-SAND C-CLAYEY		30 42		
			No Drill-Through Casing Hammer						T S C G		T-TAN/BROWN S-SOFT/LOOSE C-CLAY G-W/GRAVEL/STONES		42 83		
			No Reverse Rotary						T H C		T-TAN/BROWN H-HARD/FIRM C-CLAY		83 106		
			No Cable-tool Bit ___ in. dia...			No			G H L		G-GRAY H-HARD/FIRM L-LIMESTONE/DOLOMITE		106 181		
			No Dual Rotary			No			G H L		G-GRAY H-HARD/FIRM L-LIMESTONE/DOLOMITE		181 322		
			No Temp. Outer Casing ___ in. dia						I S N		I-WHITE S-SOFT/LOOSE N-SANDSTONE		322 369		
			No Removed? ___ depth ft. (If NO explain on back side)						T H L		T-TAN/BROWN H-HARD/FIRM L-LIMESTONE/DOLOMITE		369 460		
									R H H		R-RED H-HARD/FIRM H-SHALE		460 465		
									I S N		I-WHITE S-SOFT/LOOSE N-SANDSTONE		465 470		
									G H H		G-GRAY H-HARD/FIRM H-SHALE		470 486		
									T H L		T-TAN/BROWN H-HARD/FIRM L-LIMESTONE/DOLOMITE		486 566		
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		STEEL				Surface		181							

Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)	9. Static Water Level 11 ft. below ground surface	11. Well Is 18 in. above grade
7. Grout or Other Sealing Material Method NEAT CEMENT GROUT				10. Pump Test Pumping level 61 ft. below surface Pumping at 15 GP M for 2 Hrs. Pumping Method ? Test Pump	Developed ? Yes Disinfected ? Yes Capped ? Yes
Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement		
NEAT CEMENT GROUT	Surface	181	56 S		
				12. Notified Owner of need to fill & seal ?	Yes
				Filled & Sealed Well(s) as needed?	Yes
				13. Constructor / Supervisory Driller	Lic #
				MJS	6637
				Drill Rig Operator	Lic or Reg #
				JB	8950
				Date Signed	10-01-2025
				Date Signed	10-01-2025

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 05-22-2025
 Updated On: 10-20-2025
 Review Status: APPROVED