

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACE015		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner KASTER, SCOTT				Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address N3068 SHORE DR						Town of PESHTIGO				N3068	
City MARINETTE				State WI		Zip Code 54143				Street Address or Road Name and Number SHORE DRIVE	
County Marinette		Co. Permit #		Notification # 9839928906		Completed 09-25-2025		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) STEFFL DRILLING & PUMP INC				Lic. # 7843		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.0696 °N -87.61881 °W		Method Code GPS008	
Address 2295 66TH AVE NE WILMAR MN 56201				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 17 30 N 24 E		2. Well Type Replacement			
Hicap Permanent Well #				Common Well #		Specific Capacity 0		of previous unique well # SR305 constructed in			
3. Well serves 1 # of HOME				Hicap Well ? No		Reason for replaced or reconstructed well ? CONTAMINATION		Construction Type Drilled			
Private, potable				Hicap Property ? No							
Heat Exchange ___ # of drillholes				Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock			8. Geology		
9.875 Surface 182			<u>Yes</u> Rotary - Mud Circulation <u>No</u>			K S I K-BLACK S-SOFT/LOOSE I-SOIL-ORGANIC Surface 1					
5.895 182 624			<u>Yes</u> Rotary - Air <u>Yes</u>			T S S T-TAN/BROWN S-SOFT/LOOSE S-SAND 1 21					
			<u>No</u> Rotary - Air & Foam <u>No</u>			T M S C T-TAN/BROWN M-MEDIUM S-SAND C-CLAYEY 21 52					
			<u>No</u> Drill-Through Casing Hammer			T M C G T-TAN/BROWN M-MEDIUM C-CLAY G-W/GRAVEL/STONES 52 107					
			<u>No</u> Reverse Rotary			H L H-HARD/FIRM L-LIMESTONE/DOLOMITE 107 293					
			<u>No</u> Cable-tool Bit ___ in. dia... <u>No</u>			T H H T-TAN/BROWN H-HARD/FIRM H-SHALE 293 296					
			<u>No</u> Dual Rotary <u>No</u>			G H L G-GRAY H-HARD/FIRM L-LIMESTONE/DOLOMITE 296 309					
			<u>No</u> Temp. Outer Casing ___ in. dia			G H H G-GRAY H-HARD/FIRM H-SHALE 309 315					
			<u>No</u> Removed? ___ depth ft. (If NO explain on back side)			G H L G-GRAY H-HARD/FIRM L-LIMESTONE/DOLOMITE 315 438					
						I H N I-WHITE H-HARD/FIRM N-SANDSTONE 438 440					
						G H L G-GRAY H-HARD/FIRM L-LIMESTONE/DOLOMITE 440 469					
						R H H R-RED H-HARD/FIRM H-SHALE 469 481					
						I H N I-WHITE H-HARD/FIRM N-SANDSTONE 481 484					
						T H L T-TAN/BROWN H-HARD/FIRM L-LIMESTONE/DOLOMITE 484 511					
						I H N I-WHITE H-HARD/FIRM N-SANDSTONE 511 518					
						T H L T-TAN/BROWN H-HARD/FIRM L-LIMESTONE/DOLOMITE 518 565					
						R H H R-RED H-HARD/FIRM H-SHALE 565 572					

				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)	To (ft.)
T	H	L		T-TAN/BROWN H-HARD/FIRM L-LIMESTONE/DOLOMITE				572	574
G	H	H		G-GRAY H-HARD/FIRM H-SHALE				574	576
G	H	L		G-GRAY H-HARD/FIRM L-LIMESTONE/DOLOMITE				576	624

6. Casing, Liner, Screen				9. Static Water Level				11. Well Is	
Dia. (in.)	Screen type, material & slot size			From (ft.)	To (ft.)		10.6 ft. below ground surface		18 in. above grade
6	STEEL			0	182		10. Pump Test		Developed ? Yes
7. Grout or Other Sealing Material						Pumping level 39 ft. below surface		Disinfected ? Yes	
Method GROUTING - NEAT CEMENT						Pumping at 15 GP M for 2 Hrs.		Capped ? Yes	
Kind of Sealing Material		From (ft.)	To (ft.)	# Sacks Cement		Pumping Method ? Test Pump			
NEAT CEMENT GROUT		Surface	182	52 S					
12. Notified Owner of need to fill & seal ?								Yes	
Filled & Sealed Well(s) as needed?								Yes	

13. Constructor / Supervisory Driller		Lic #	Date Signed
MJS		6637	10-01-2025
Drill Rig Operator		Lic or Reg #	Date Signed
AK		8951	10-01-2025

4a. Potential Contamination Sources		Is the well located in floodplain ? <u>No</u>	
Comment:			
Created On: 05-22-2025		Updated On: 10-20-2025 Review Status: APPROVED	