

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACE023		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner PAPPIN, TIM						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 18 6TH STREET						Town of BELLE PLAINE						N2988	
City CLINTONVILLE						State WI		Zip Code 54929				Street Address or Road Name and Number	
GRASS LAKE ROAD, CLINTONVILLE, WI 54929						Subdivision Name				Lot #		Block #	
County Shawano		Co. Permit #		Notification # 9889318901		Completed 02-23-2026		Latitude / Longitude in Decimal Degree (DD)				Method Code	
Well Constructor (Business Name) SHAWANO WELL DRILLING INC				Lic. # 6001		Facility ID # (Public Wells)				44.6957 °N -88.6505 °W		GPS008	
Address W9618 ANGLE RD SHAWANO WI 54166				Well Plan Approval #		SE SE		Section 27		Township 26 N		Range 15 E	
				Approval Date (mm-dd-yyyy)		or Govt Lot #							
Hicap Permanent Well #		Common Well #		Specific Capacity 0.6		2. Well Type New Well				of previous unique well # constructed in			
3. Well serves 1 # of HOME						Hicap Well ? No		Reason for replaced or reconstructed well ?					
Private, potable Drillhole						Hicap Property ? No							
Heat Exchange ___ # of drillholes						Hicap Potable ? No		Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock			
6		Surface		83		No Rotary - Mud Circulation				No			
						No Rotary - Air				No			
						No Rotary - Air & Foam				No			
						No Drill-Through Casing Hammer							
						No Reverse Rotary							
						No Cable-tool Bit ___ in. dia...				No			
						No Dual Rotary				No			
						No Temp. Outer Casing ___ in. dia							
						No Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
T	N	S	S	T-TAN/BROWN N-FINE S-SAND S-SANDY				Surface		32			
G	N	M	S	G-GRAY N-FINE M-SILT S-SANDY				32		42			
R	V	C	S	R-RED V-NON-CAVING C-CLAY S-SANDY				42		75			
T	M	S	S	T-TAN/BROWN M-MEDIUM S-SAND S-SANDY				75		83			
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		STEEL ASTM A53 18.97LBS/FT WHEATLAND WELDED				Surface		80					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
6		STAINLESS STEEL 12 SLOT WIRE WRAP				80		83					
7. Grout or Other Sealing Material													
Method MOUNDED													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
GRANULAR BENTONITE				Surface				1 S					
9. Static Water Level													
21 ft. below ground surface													
10. Pump Test													
Pumping level 65 ft. below surface													
Pumping at 25 GP M for 1 Hrs.													
Pumping Method ? Airlift													
11. Well Is													
20 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ? No													
Filled & Sealed Well(s) as needed? No													
13. Constructor / Supervisory Driller													
JDD				Lic # 6331		Date Signed 02-23-2026							
Drill Rig Operator				Lic or Reg #		Date Signed							
JL				7417		02-23-2026							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Sewer - Building Sanitary		29

Comment:

Created On: 05-22-2025

Updated On: 03-27-2026

Review Status: APPROVED