Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACE292

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: WIRSING, MOLLY	Phone #
Mailing Address: 24010 STATE HWY 13	
City: CORNUCOPIA	State: WI — Zip Code: 54827
County: Bayfield	Co. Permit #: WI — Notification #: 9879946501 — Completed: 05-27-2025

1. Well Location

Town of BELL	Fire # (if avail.): 24010
Street Address or Road Name and Number: STATE HWY 13	
Subdivision Name	Lot # — Block #

Well Constructor (Business Name): KOSTAC, CHRISTOPHER L	Lic. #: 7166	Facility ID # (Public Wells)	
Address: KOSTAC WELL DRILLING AND REPAIR 60358 JOHN JOHNSON RD ASHLAND WI 54806		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 3.8	

Latitude / Longitude in Decimal Degree (DD): 46.86123 °N -91.07161 °W — Method Code: GPS008

SW	SW	Section	Township	Range
or Govt Lot #		25	51 N	6 W

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
OLD WELL WAS THIN WALL CASING AND BADLY DETERIORATING

Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	70

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit 6in. dia...	No
No	Dual Rotary	Yes
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R		C	S	R-RED C-CLAY S-SANDY	Surface	43
		N		N-SANDSTONE	43	70

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL ASTM 53 PLAIN END	Surface	45
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	45	

9. Static Water Level
21 ft. below ground surface

10. Pump Test
Pumping level 25 ft. below surface
Pumping at 15 GP M for 24 Hrs.
Pumping Method ? Test Pump

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
CLK	7166	07-07-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		35

Comment:

Created On: 06-02-2025 Updated On: 07-22-2025 Review Status: APPROVED