Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACE353

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BRANDON MEYER			Phone #
Mailing Address: N3233 HOLMGREN DR			
City: LA CROSSE	State: WI	Zip Code: 54601	
County: La Crosse	Co. Permit #: 2024046	Notification #: 9839002301	Completed: 06-02-2025

Well Constructor (Business Name): HOLLER, WAYNE	Lic. #: 4668	Facility ID # (Public Wells)	
Address: HOLLER PLUMBING & WELL DRILLING N2995 SMITH VALLEY RD LA CROSSE WI 54601-2935		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.8	

1. Well Location

Fire # (if avail.)

Town of BARRE

Street Address or Road Name and Number: HOLMGREN DR

Subdivision Name: IST ADDN TO FOX HOLLOW	Lot #: 22	Block #

Latitude / Longitude in Decimal Degree (DD): 43.83872 °N -91.12462 °W			Method Code: GPS008
NE NW or Govt Lot #	Section: 29	Township: 16 N	Range: 6 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	156
6	156	180

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 6in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 10in. dia	
Yes	Removed? 14depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	S	C	M	T-TAN/BROWN S-SOFT/LOOSE C-CLAY M-SILTY	Surface	11
E	H	H	H	E-GREEN H-HARD/FIRM H-SHALE H-SHALEY	11	35
Y	S	N	N	Y-YELLOW S-SOFT/LOOSE N-SANDSTONE N-W/SANDSTONE	35	145
Y	H	N	N	Y-YELLOW H-HARD/FIRM N-SANDSTONE N-W/SANDSTONE	145	180

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM-A53.280 WALL WHEATLAND USA PLAIN END WELD	Surface	158
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

134 ft. below ground surface

10. Pump Test

Pumping level 153 ft. below surface

Pumping at 15 GP M for 14 Hrs.

Pumping Method ? Test Pump

11. Well Is

22 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	156	53 S

12. Notified Owner of need to fill & seal ? No

NONE EXIST

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
WH	4668	06-09-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		80
POWTS dispersal component (soil absorption unit or mound)		100
Building Drain - Sanitary		31
Landfill	>	1200

Comment:

Created On: 06-03-2025 Updated On: 10-15-2026 Review Status: APPROVED