

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACE597		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner STASECK, GARY						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address W4995 HALO RIDGE LANE						Town of NECEDAH						W4995			
City NECEDAH						State WI		Zip Code 53950				Street Address or Road Name and Number W4995 HALO RIDGE LANE			
County Juneau		Co. Permit #		Notification # 9918301301		Completed 06-11-2025		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) LANGE PLUMBING INC				Lic. # 7538		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.0052 °N -90.01696 °W				Method Code SCR002	
Address N5769 HWY 58 NEW LISBON WI 53950				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 28 18 N 4 E		2. Well Type Replacement				of previous unique well # constructed in			
Hicap Permanent Well #				Common Well #		Specific Capacity				Reason for replaced or reconstructed well ? PLUGGED WELL					
3. Well serves 1 # of HOME						Hicap Well ? No		Construction Type Driven Point							
Private, potable						Hicap Property ? No									
Heat Exchange ___ # of drillholes						Hicap Potable ? No									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
1.25 Surface 28			No Rotary - Mud Circulation No												
1.25 28 31			No Rotary - Air No												
			No Rotary - Air & Foam No												
			No Drill-Through Casing Hammer												
			No Reverse Rotary												
			No Cable-tool Bit ___ in. dia... No												
			No Dual Rotary No												
6. Casing, Liner, Screen			No Temp. Outer Casing ___ in. dia												
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		8. Geology					
1.25		ASTM A-53 1 1/4" SCHEDULE 40 GRADE-A				Surface		28		9. Static Water Level 17 ft. below ground surface					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test					
1.25		80 GAUGE				28		31		Developed ? Yes					
Pumping level ___ ft. below surface										Disinfected ? Yes					
Pumping at ___ GP for ___ Hrs.										Capped ? Yes					
Pumping Method ?										11. Well Is					
7. Grout or Other Sealing Material										12. Notified Owner of need to fill & seal ? No					
Method										Filled & Sealed Well(s) as needed? Yes					
13. Constructor / Supervisory Driller								Lic #		Date Signed					
SL								4553		07-03-2025					
Drill Rig Operator								Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	=	50	Septic or Holding, or POWTS Tank	=	32

Comment:

WILL NEED TO FILE VARIANCE SOON DUE TO THE DRAIN FIELD DISTANCE NOT MEETING THE MINIMUM REQUIREMENT. THE SEPTIC DISTANCE IS CORRECT HOWEVER THE DRAIN FIELD IS ONLY 42' AWAY FROM THE WELL. I PUT 50' FOR NOW SO I CAN SAVE THE REPORT.

Created On: 06-10-2025

Updated On: 09-23-2025

Review Status: APPROVED