Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACE732

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MEACHAM, PAT	Phone #
Mailing Address: W10375 NELSON ROAD	
City: ATHELSTANE	State: WI — Zip Code: 54104

County	Co. Permit #	Notification #	Completed
Marinette	9858021101	9858021101	06-09-2025

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
MAIDEN LAKE PLUMBING LLC	8305	

Address: 15003 STATE HWY 32, LAKEWOOD WI 54138

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.5

3. Well serves 1 # of GARAGE

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

1. Well Location

Town of ATHELSTANE

Fire # (if avail.): W10375

Street Address or Road Name and Number: TALL TIMBER DRIVE

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
45.37213 °N -88.11204 °W	SCR002

SE SW or Govt Lot #	Section	Township	Range
	34	34 N	19 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Driven Point

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	29

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	WHEATLAND GALV, ASTM A53, 300 PSI, THREADED ENDS WITH DRIVE COUPLINGS	Surface	26
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
2	MIDWEST 60 GAZ	26	29

7. Grout or Other Sealing Material

Method

8. Geology

9. Static Water Level

13 ft. below ground surface

10. Pump Test

Pumping level 26 ft. below surface

Pumping at 7 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
NP	8119	06-12-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 06-12-2025 Updated On: 07-07-2025 Review Status: APPROVED