

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACE732		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner MEACHAM, PAT						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address W10375 NELSON ROAD								Town of ATHELSTANE				W10375	
City ATHELSTANE						State WI		Zip Code 54104				Street Address or Road Name and Number TALL TIMBER DRIVE	
County Marinette		Co. Permit # 9858021101		Notification # 9858021101		Completed 06-09-2025		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) MAIDEN LAKE PLUMBING LLC				Lic. # 8305		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.37213 °N -88.11204 °W				Method Code SCR002	
Address 15003 STATE HWY 32 LAKEWOOD WI 54138				Well Plan Approval #		SE SW Section Township Range or Govt Lot # 34 34 N 19 E		2. Well Type New Well				of previous unique well # constructed in	
Hicap Permanent Well #				Common Well #		Specific Capacity 0.5		Reason for replaced or reconstructed well ?				Construction Type Driven Point	
3. Well serves 1 # of GARAGE				Hicap Well ? No		Private, potable		Hicap Property ? No		Heat Exchange ___ # of drillholes		Hicap Potable ? No	
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock					
2		Surface		29		No Rotary - Mud Circulation		No					
						No Rotary - Air		No					
						No Rotary - Air & Foam		No					
						No Drill-Through Casing Hammer							
						No Reverse Rotary							
						No Cable-tool Bit ___ in. dia...		No					
						No Dual Rotary		No					
6. Casing, Liner, Screen				No Temp. Outer Casing ___ in. dia									
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
2		WHEATLAND GALV, ASTM A53, 300 PSI, THREADED ENDS WITH DRIVE COUPLINGS				Surface		26					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
2		MIDWEST 60 GAZ				26		29					
7. Grout or Other Sealing Material Method												8. Geology	
9. Static Water Level 13 ft. below ground surface												11. Well Is 18 in. above grade	
10. Pump Test Pumping level 26 ft. below surface Pumping at 7 GP M for 1 Hrs. Pumping Method ? Test Pump												Developed ? Yes Disinfected ? Yes Capped ? Yes	
12. Notified Owner of need to fill & seal ? No												Filled & Sealed Well(s) as needed? No	
13. Constructor / Supervisory Driller						Lic #		Date Signed					
NP						8119		06-12-2025					
Drill Rig Operator						Lic or Reg #		Date Signed					

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 06-12-2025

Updated On: 07-07-2025

Review Status: APPROVED