

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACF049		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A						
Property Owner STOUTENBURG TY					Phone #			1. Well Location				Fire # (if avail.)				
Mailing Address W9288 BIG SAND LK.RD.								Town of MINONG				W9288				
City MINONG					State WI		Zip Code 54859					Street Address or Road Name and Number W9288 BIG SAND LK.RD.				
County Washburn		Co. Permit #		Notification # 9823143001			Completed 05-02-2025			Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) RUTHERFORD, JEFFREY J				Lic. # 6202		Facility ID # (Public Wells)			Latitude / Longitude in Decimal Degree (DD) 46.1445 °N -92.0175 °W				Method Code OTH001			
Address H2O WELL & PUMP N11455 MC CLAIN LAKE RD TREGO WI 54888				Well Plan Approval #			SW SE		Section 5		Township 42 N		Range 13 W			
Hicap Permanent Well #				Common Well #		Specific Capacity 0.8			2. Well Type New Well							
3. Well serves 1 # of HOME				Hicap Well ? No			of previous unique well # constructed in									
Private,potable				Hicap Property ? No			Reason for replaced or reconstructed well ?									
Heat Exchange ___ # of drillholes				Hicap Potable ? No			Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE																
5. Drillhole Dimensions and Construction Method																
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock						
4		Surface		37		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary Yes Cable-tool Bit 3.75in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				Geology Codes T E S Type, Caving/Noncaving, Color, Hardness, etc... T-TAN/BROWN E-CLEAN S-SAND						
6. Casing, Liner, Screen																
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level						
4		ASTM53 SA-53B 4.5X237 PARAGON WELDED				Surface		34		7 ft. below ground surface						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test						
3		STAINLESS 12 SLOT				34		37		Pumping level 20 ft. below surface Pumping at 10 GP M for 10 Hrs. Pumping Method ? Test Pump						
7. Grout or Other Sealing Material Method MOUNDED BENTONITE																
11. Well Is 16 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes																
12. Notified Owner of need to fill & seal ? No Filled & Sealed Well(s) as needed? No																
13. Constructor / Supervisory Driller																
JR								Lic # 6202		Date Signed 06-23-2025						
Drill Rig Operator								Lic or Reg #		Date Signed						
JR										06-23-2025						

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		52

Comment:

Created On: 06-23-2025

Updated On: 09-23-2025

Review Status: APPROVED