

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACF051		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner BUSS ROD				Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 1180 S.SHORE RD.						Town of BARNES				1180	
City GORDON				State WI		Zip Code 54838				Street Address or Road Name and Number 1180 S. SHORE RD.	
County Bayfield		Co. Permit #		Notification # 9636777901		Completed 05-07-2025		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) RUTHERFORD, JEFFREY J				Lic. # 6202		Facility ID # (Public Wells) M		Latitude / Longitude in Decimal Degree (DD) 46.288 °N -91.5452 °W		Method Code OTH001	
Address H2O WELL & PUMP N11455 MC CLAIN LAKE RD TREGO WI 54888				Well Plan Approval # M		Approval Date (mm-dd-yyyy) 11-06-2024		SE SW Section Township Range or Govt Lot # 18 44 N 9 W		2. Well Type Replacement of previous unique well # constructed in	
Hicap Permanent Well #		Common Well #		Specific Capacity 1.1		Reason for replaced or reconstructed well ? LOW VOLUME SANDPOINT		Construction Type Drilled			
3. Well serves 1 # of HOME Private,potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.)	
4		Surface		52		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary Yes Cable-tool Bit 3.75in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)		T A S T-TAN/BROWN A-COARSE S-SAND Surface 52			
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is 16 in. above grade	
4		ASTM53 SA-53B 4.5X237 PARAGON WELDED				Surface		49		Developed ? Yes Disinfected ? Yes Capped ? Yes	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
3		STAINLESS 10 SLOT				49		52			
7. Grout or Other Sealing Material Method MOUNDED BENTONITE											
9. Static Water Level 36 ft. below ground surface											
10. Pump Test Pumping level 45 ft. below surface Pumping at 10 GP M for 10 Hrs. Pumping Method ? Test Pump											
12. Notified Owner of need to fill & seal ? Yes Filled & Sealed Well(s) as needed? Yes											
13. Constructor / Supervisory Driller								Lic #		Date Signed	
JR								6202		06-23-2025	
Drill Rig Operator								Lic or Reg #		Date Signed	
JR										06-23-2025	

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		65

Comment:

Created On: 06-23-2025

Updated On: 09-23-2025

Review Status: APPROVED