

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACF197		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner RIESE, JAY						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 1005 SHADOWOOD CIRCLE #2								Town of NEW CHESTER				2527					
City WEST BEND						State WI		Zip Code 53095				Street Address or Road Name and Number FIRST AVENUE					
County Adams		Co. Permit #		Notification # 9930882301		Completed 07-15-2025		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) FARAGO PLBG & TRENCHING INC				Lic. # 126		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.88635 °N -89.59821 °W				Method Code GPS008			
Address 229 SHORT ST PLAINFIELD WI 54966				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 12 16 N 7 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 0													
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		116		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>Yes</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)				S		S-SAND		Surface		15	
										C		C-CLAY		15		35	
										Y		Y-SAND & GRAVEL		35		116	
6. Casing, Liner, Screen												8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 53 ft. below ground surface				11. Well Is 24 in. above grade			
6		IPSCO A53 6.625 X.280 WALL WELDED TOGETHER WEIGHT 2,124.64				Surface		112		10. Pump Test Pumping level 54 ft. below surface Pumping at 20 GP M for 2 Hrs. Pumping Method ? Test Pump				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
6		#10 SLOT S&S				112		116									
7. Grout or Other Sealing Material Method MOUNDED												12. Notified Owner of need to fill & seal ? No					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No							
BENT ALONG CASING				Surface													
13. Constructor / Supervisory Driller												Lic #		Date Signed			
CF												8145		07-16-2025			
Drill Rig Operator												Lic or Reg #		Date Signed			

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 06-26-2025

Updated On: 08-27-2025

Review Status: APPROVED