Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACF230

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: STENDALEN FAMILY TRUST			Phone #
Mailing Address: W7814 COUNTY RD MH			
City: HOLMEN	State: WI	Zip Code: 54636	
County: La Crosse	Co. Permit #: 2025050	Notification #: 9931561401	Completed: 07-01-2025

Well Constructor (Business Name): WELL PROS PUMP & WELL DRILLING SERVICES LLC	Lic. #: 7970	Facility ID # (Public Wells):
Address: N5550 CTY RD Z STE 3B ONALASKA WI 54650		Well Plan Approval #:
		Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.8

3. Well serves 1 # of HOMES
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location
Village of HOLMEN

Fire # (if avail.): W7814

Street Address or Road Name and Number: W7814 COUNTY RD MH

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
43.97053 °N -91.29651 °W	SCR002

SW	SE	Section	Township	Range
or Govt Lot #		2	17 N	8 W

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
FAILED

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	129

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit 4in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	Y-SAND & GRAVEL	Surface	129

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	BLACK STEEL, 11#/FT,ASTMA 53, WHEATLAND, T&C	Surface	126
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3	TYPE 304 STAINLESS STEEL 12 SLOT	126	129

9. Static Water Level
80 ft. below ground surface

10. Pump Test
Pumping level 100 ft. below surface
Pumping at 15 GP M for 3 Hrs.
Pumping Method ? Test Pump

11. Well Is
20 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	126	4 S

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
MI	7411	07-01-2025
Drill Rig Operator	Lic or Reg #	Date Signed
ZA	9291	07-01-2025

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 07-01-2025 Updated On: 10-15-2026 Review Status: APPROVED