Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACF347

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KATHLEEN KUZNIECKI	Phone #
Mailing Address: W229 S 8785 MULBERRY ST.	
City: BIG BEND	State: WI — Zip Code: 53103
County: Burnett	Co. Permit #: — Notification #: 9937172201 — Completed: 07-01-2025
Well Constructor (Business Name): ARNOLD, WILLIAM JR	Lic. #: 4514 — Facility ID # (Public Wells):
Address: BILL ARNOLD PUMP & WELL 28290 STATE RD 35 DANBURY WI 54830	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity:

1. Well Location

Town of MEENON	Fire # (if avail.): 6762
Street Address or Road Name and Number: 6762 N. BASS LAKE RD.	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.86298 °N -92.3312 °W	Method Code: SCR002
SW SE or Govt Lot #:	Section: 15 — Township: 39 N — Range: 16 W

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: PLUGGED POINT

Construction Type: Driven Point

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	45

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T Q S	T-TAN/BROWN Q-CAVING S-SAND	Surface	45

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	GALV. STEEL SCH 40 ASTM A53 THREADED AND COUPLED	Surface	41
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
2	SIMMONS 1753-1 60GA STAINLESS	41	45

9. Static Water Level

31 ft. below ground surface

10. Pump Test

Pumping level 31 ft. below surface

Pumping at 8 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? No

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
WA	4514	04-25-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		35	POWTS dispersal component (soil absorption unit or mound)		75

Comment:

Created On: 07-01-2025 Updated On: 07-18-2025 Review Status: APPROVED